

Sample Information:

Type : Potable Water
 Origin: Distribution

LABORATORY RESULTS

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

Fort Ann CSD

1 Catherine St

Fort Ann, NY 12827

Attn To : Kevin Lovely

Federal ID :

Collected : 09/26/2016 4:20 AM Point No

Received : 09/27/2016 12:10 PM Location:

Collected By : CLIENT

Lab No. : 1610034-001

Client Sample ID. : HF1

Analytical Method: E200.8 : IOC

Analyst: CM

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	3.2		1	ug/L	15	10/15/2016 4:19 PM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.


S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with * Exceed Regulatory Limit(s). Limit noted.

Date Reported : 10/17/2016



Project Manager : Wayne Bryce

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

Sample Information:

Type : Potable Water
 Origin: Distribution

LABORATORY RESULTS

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

Fort Ann CSD

1 Catherine St

Fort Ann, NY 12827

Attn To : Kevin Lovely

Federal ID :

Collected : 09/26/2016 4:22 AM Point No

Received : 09/27/2016 12:10 PM Location:

Collected By : CLIENT

Lab No. : 1610034-002

Client Sample ID. : 102 A

Analytical Method: E200.8 : IOC

Analyst: CM

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	6.3		1	ug/L	15	10/15/2016 4:22 PM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.


S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with * Exceed Regulatory Limit(s). Limit noted.

Date Reported : 10/17/2016



Project Manager : Wayne Bryce

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

Sample Information:

Type : Potable Water
 Origin: Distribution

LABORATORY RESULTS

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

Fort Ann CSD

1 Catherine St

Fort Ann, NY 12827

Attn To : Kevin Lovely

Federal ID :

Collected : 09/26/2016 4:25 AM Point No

Received : 09/27/2016 12:10 PM Location:

Collected By : CLIENT

Lab No. : 1610034-003

Client Sample ID. : 102 B

Analytical Method: E200.8 : IOC

Analyst: CM

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	6.3		1	ug/L	15	10/15/2016 4:25 PM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.

S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with * Exceed Regulatory Limit(s). Limit noted.

Date Reported : 10/17/2016



Project Manager : Wayne Bryce

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

Sample Information:

Type : Potable Water
 Origin: Distribution

LABORATORY RESULTS

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

Fort Ann CSD

1 Catherine St

Fort Ann, NY 12827

Attn To : Kevin Lovely

Federal ID :

Collected : 09/26/2016 4:28 AM Point No

Received : 09/27/2016 12:10 PM Location:

Collected By : CLIENT

Lab No. : 1610034-004

Client Sample ID. : 102 C

Analytical Method: E200.8 : IOC

Analyst: CM

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	7.1		1	ug/L	15	10/15/2016 4:28 PM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.


S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with * Exceed Regulatory Limit(s). Limit noted.

Date Reported : 10/17/2016



Project Manager : Wayne Bryce

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

Sample Information:

Type : Potable Water
 Origin: Distribution

LABORATORY RESULTS

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

Fort Ann CSD

1 Catherine St

Fort Ann, NY 12827

Attn To : Kevin Lovely

Federal ID :

Collected : 09/26/2016 4:30 AM Point No

Received : 09/27/2016 12:10 PM Location:

Collected By : CLIENT

Lab No. : 1610034-005

Client Sample ID. : 102 D

Analytical Method: E200.8 : IOC

Analyst: CM

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	* 24	*	1	ug/L	15	10/15/2016 4:31 PM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.

S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with * Exceed Regulatory Limit(s). Limit noted.

Date Reported : 10/17/2016



Project Manager : Wayne Bryce

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

Sample Information:

Type : Potable Water
 Origin: Distribution

LABORATORY RESULTS

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

Fort Ann CSD

1 Catherine St

Fort Ann, NY 12827

Attn To : Kevin Lovely

Federal ID :

Collected : 09/26/2016 4:31 AM Point No

Received : 09/27/2016 12:10 PM Location:

Collected By : CLIENT

Lab No. : 1610034-006

Client Sample ID. : 102 E

Analytical Method: E200.8 : IOC

Analyst: CM

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	13		1	ug/L	15	10/15/2016 4:34 PM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.


S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with * Exceed Regulatory Limit(s). Limit noted.

Date Reported : 10/17/2016



Project Manager : Wayne Bryce

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

Sample Information:

Type : Potable Water
 Origin: Distribution

LABORATORY RESULTS

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

Fort Ann CSD

1 Catherine St

Fort Ann, NY 12827

Attn To : Kevin Lovely

Federal ID :

Collected : 09/26/2016 4:30 AM Point No

Received : 09/27/2016 12:10 PM Location:

Collected By : CLIENT

Lab No. : 1610034-007

Client Sample ID. : 102 F

Analytical Method: E200.8 : IOC

Analyst: CM

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	9.3		1	ug/L	15	10/15/2016 4:37 PM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.


S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with * Exceed Regulatory Limit(s). Limit noted.

Date Reported : 10/17/2016



Project Manager : Wayne Bryce

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

Sample Information:

Type : Potable Water
 Origin: Distribution

LABORATORY RESULTS

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

Fort Ann CSD

1 Catherine St

Fort Ann, NY 12827

Attn To : Kevin Lovely

Federal ID :

Collected : 09/26/2016 4:32 AM Point No

Received : 09/27/2016 12:10 PM Location:

Collected By : CLIENT

Lab No. : 1610034-008

Client Sample ID. : 102 G

Analytical Method: E200.8 : IOC

Analyst: CM

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	* 22	*	1	ug/L	15	10/15/2016 4:54 PM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.


S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with * Exceed Regulatory Limit(s). Limit noted.

Date Reported : 10/17/2016



Project Manager : Wayne Bryce

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

Sample Information:

Type : Potable Water
 Origin: Distribution

LABORATORY RESULTS

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

Fort Ann CSD

1 Catherine St

Fort Ann, NY 12827

Attn To : Kevin Lovely

Federal ID :

Collected : 09/26/2016 4:33 AM Point No

Received : 09/27/2016 12:10 PM Location:

Collected By : CLIENT

Lab No. : 1610034-009

Client Sample ID. : 102 H

Analytical Method: E200.8 : IOC

Analyst: CM

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	* 28	*	1	ug/L	15	10/15/2016 4:57 PM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.


S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with * Exceed Regulatory Limit(s). Limit noted.

Date Reported : 10/17/2016



Project Manager : Wayne Bryce

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

Sample Information:

Type : Potable Water
Origin: Distribution

LABORATORY RESULTS

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

Fort Ann CSD

1 Catherine St

Fort Ann, NY 12827

Attn To : Kevin Lovely

Federal ID :

Collected : 09/26/2016 4:34 AM Point No

Received : 09/27/2016 12:10 PM Location:

Collected By : CLIENT

Lab No. : 1610034-010

Client Sample ID. : 102 EW

Analytical Method: E200.8 : IOC

Analyst: CM

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	1.1		1	ug/L	15	10/15/2016 5:00 PM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.


S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with * Exceed Regulatory Limit(s). Limit noted.

Date Reported : 10/17/2016



Project Manager : Wayne Bryce

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

Sample Information:

Type : Potable Water
 Origin: Distribution

LABORATORY RESULTS

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

Fort Ann CSD

1 Catherine St

Fort Ann, NY 12827

Attn To : Kevin Lovely

Federal ID :

Collected : 09/26/2016 4:35 AM Point No

Received : 09/27/2016 12:10 PM Location:

Collected By : CLIENT

Lab No. : 1610034-011

Client Sample ID. : 102 I

Analytical Method: E200.8 : IOC

Analyst: CM

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	5.5		1	ug/L	15	10/15/2016 5:03 PM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.

S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with * Exceed Regulatory Limit(s). Limit noted.

Date Reported : 10/17/2016



Project Manager : Wayne Bryce

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

Sample Information:

Type : Potable Water
 Origin: Distribution

LABORATORY RESULTS

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

Fort Ann CSD

1 Catherine St

Fort Ann, NY 12827

Attn To : Kevin Lovely

Federal ID :

Collected : 09/26/2016 4:40 AM Point No

Received : 09/27/2016 12:10 PM Location:

Collected By : CLIENT

Lab No. : 1610034-012

Client Sample ID. : 103 A

Analytical Method: E200.8 : IOC

Analyst: CM

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	7.2		1	ug/L	15	10/15/2016 5:06 PM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.


S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with * Exceed Regulatory Limit(s). Limit noted.

Date Reported : 10/17/2016



Project Manager : Wayne Bryce

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

Sample Information:

Type : Potable Water
 Origin: Distribution

LABORATORY RESULTS

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

Fort Ann CSD

1 Catherine St

Fort Ann, NY 12827

Attn To : Kevin Lovely

Federal ID :

Collected : 09/26/2016 4:43 AM Point No

Received : 09/27/2016 12:10 PM Location:

Collected By : CLIENT

Lab No. : 1610034-013

Client Sample ID. : B122 A

Analytical Method: E200.8 : IOC

Analyst: CM

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	9.8		1	ug/L	15	10/15/2016 5:09 PM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.

S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with * Exceed Regulatory Limit(s). Limit noted.

Date Reported : 10/17/2016



Project Manager : Wayne Bryce

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

Sample Information:

Type : Potable Water
 Origin: Distribution

LABORATORY RESULTS

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

Fort Ann CSD

1 Catherine St

Fort Ann, NY 12827

Attn To : Kevin Lovely

Federal ID :

Collected : 09/26/2016 4:44 AM Point No

Received : 09/27/2016 12:10 PM Location:

Collected By : CLIENT

Lab No. : 1610034-014

Client Sample ID. : B121 A

Analytical Method: E200.8 : IOC

Analyst: CM

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	5.1		1	ug/L	15	10/15/2016 5:12 PM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.


S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with * Exceed Regulatory Limit(s). Limit noted.

Date Reported : 10/17/2016



Project Manager : Wayne Bryce

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

Sample Information:

Type : Potable Water
 Origin: Distribution

LABORATORY RESULTS

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

Fort Ann CSD

1 Catherine St

Fort Ann, NY 12827

Attn To : Kevin Lovely

Federal ID :

Collected : 09/26/2016 4:44 AM Point No

Received : 09/27/2016 12:10 PM Location:

Collected By : CLIENT

Lab No. : 1610034-015

Client Sample ID. : B121 B

Analytical Method: E200.8 : IOC

Analyst: CM

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	8.0		1	ug/L	15	10/15/2016 5:15 PM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.


S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with * Exceed Regulatory Limit(s). Limit noted.

Date Reported : 10/17/2016



Project Manager : Wayne Bryce

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

Sample Information:

Type : Potable Water
 Origin: Distribution

LABORATORY RESULTS

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

Fort Ann CSD

1 Catherine St

Fort Ann, NY 12827

Attn To : Kevin Lovely

Federal ID :

Collected : 09/26/2016 4:45 AM Point No

Received : 09/27/2016 12:10 PM Location:

Collected By : CLIENT

Lab No. : 1610034-016

Client Sample ID. : B122 B

Analytical Method: E200.8 : IOC

Analyst: CM

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	* 37	*	1	ug/L	15	10/15/2016 5:29 PM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.


S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with * Exceed Regulatory Limit(s). Limit noted.

Date Reported : 10/17/2016



Project Manager : Wayne Bryce

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

Sample Information:

Type : Potable Water
 Origin: Distribution

LABORATORY RESULTS

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

Fort Ann CSD

1 Catherine St

Fort Ann, NY 12827

Attn To : Kevin Lovely

Federal ID :

Collected : 09/26/2016 4:47 AM Point No

Received : 09/27/2016 12:10 PM Location:

Collected By : CLIENT

Lab No. : 1610034-017

Client Sample ID. : C-2

Analytical Method: E200.8 : IOC

Analyst: CM

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	* 18	*	1	ug/L	15	10/15/2016 5:32 PM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.


S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with * Exceed Regulatory Limit(s). Limit noted.

Date Reported : 10/17/2016



Project Manager : Wayne Bryce

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

Sample Information:

Type : Potable Water
 Origin: Distribution

LABORATORY RESULTS

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

Fort Ann CSD

1 Catherine St

Fort Ann, NY 12827

Attn To : Kevin Lovely

Federal ID :

Collected : 09/26/2016 4:50 AM Point No

Received : 09/27/2016 12:10 PM Location:

Collected By : CLIENT

Lab No. : 1610034-018

Client Sample ID. : BR4 B

Analytical Method: E200.8 : IOC

Analyst: CM

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	6.9		1	ug/L	15	10/15/2016 5:35 PM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.


S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with * Exceed Regulatory Limit(s). Limit noted.

Date Reported : 10/17/2016



Project Manager : Wayne Bryce

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

Sample Information:

Type : Potable Water
 Origin: Distribution

LABORATORY RESULTS

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

Fort Ann CSD

1 Catherine St

Fort Ann, NY 12827

Attn To : Kevin Lovely

Federal ID :

Collected : 09/26/2016 4:50 AM Point No

Received : 09/27/2016 12:10 PM Location:

Collected By : CLIENT

Lab No. : 1610034-019

Client Sample ID. : BR4 A

Analytical Method: E200.8 : IOC

Analyst: CM

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	8.3		1	ug/L	15	10/15/2016 5:38 PM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.

S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with * Exceed Regulatory Limit(s). Limit noted.

Date Reported : 10/17/2016



Project Manager : Wayne Bryce

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

Sample Information:

Type : Potable Water
 Origin: Distribution

LABORATORY RESULTS

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

Fort Ann CSD

1 Catherine St

Fort Ann, NY 12827

Attn To : Kevin Lovely

Federal ID :

Collected : 09/26/2016 4:52 AM Point No

Received : 09/27/2016 12:10 PM Location:

Collected By : CLIENT

Lab No. : 1610034-020

Client Sample ID. : HF2 A

Analytical Method: E200.8 : IOC

Analyst: CM

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	1.3		1	ug/L	15	10/15/2016 5:41 PM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.


S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with * Exceed Regulatory Limit(s). Limit noted.

Date Reported : 10/17/2016



Project Manager : Wayne Bryce

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

Sample Information:

Type : Potable Water
 Origin: Distribution

LABORATORY RESULTS

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

Fort Ann CSD

1 Catherine St

Fort Ann, NY 12827

Attn To : Kevin Lovely

Federal ID :

Collected : 09/26/2016 4:52 AM Point No

Received : 09/27/2016 12:10 PM Location:

Collected By : CLIENT

Lab No. : 1610034-021

Client Sample ID. : HF2 B

Analytical Method: E200.8 : IOC

Analyst: CM

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	< 1.0		1	ug/L	15	10/15/2016 5:44 PM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.

S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with * Exceed Regulatory Limit(s). Limit noted.

Date Reported : 10/17/2016



Project Manager : Wayne Bryce

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

Sample Information:

Type : Potable Water
 Origin: Distribution

LABORATORY RESULTS

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

Fort Ann CSD

1 Catherine St

Fort Ann, NY 12827

Attn To : Kevin Lovely

Federal ID :

Collected : 09/26/2016 4:54 AM Point No

Received : 09/27/2016 12:10 PM Location:

Collected By : CLIENT

Lab No. : 1610034-022

Client Sample ID. : BR5 A

Analytical Method: E200.8 : IOC

Analyst: CM

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	6.2		1	ug/L	15	10/15/2016 5:47 PM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.


S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with * Exceed Regulatory Limit(s). Limit noted.

Date Reported : 10/17/2016



Project Manager : Wayne Bryce

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

Sample Information:

Type : Potable Water
Origin: Distribution

LABORATORY RESULTS

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

Fort Ann CSD

1 Catherine St

Fort Ann, NY 12827

Attn To : Kevin Lovely

Federal ID :

Collected : 09/26/2016 4:54 AM Point No

Received : 09/27/2016 12:10 PM Location:

Collected By : CLIENT

Lab No. : 1610034-023

Client Sample ID. : BR5 B

Analytical Method: E200.8 : IOC

Analyst: CM

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	13		1	ug/L	15	10/15/2016 5:50 PM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.

S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with * Exceed Regulatory Limit(s). Limit noted.

Date Reported : 10/17/2016



Project Manager : Wayne Bryce

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

Sample Information:

Type : Potable Water
 Origin: Distribution

LABORATORY RESULTS

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

Fort Ann CSD

1 Catherine St

Fort Ann, NY 12827

Attn To : Kevin Lovely

Federal ID :

Collected : 09/26/2016 4:57 AM Point No

Received : 09/27/2016 12:10 PM Location:

Collected By : CLIENT

Lab No. : 1610034-024

Client Sample ID. : B120 A

Analytical Method: E200.8 : IOC

Analyst: CM

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	* 46	*	1	ug/L	15	10/15/2016 6:04 PM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.


S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with * Exceed Regulatory Limit(s). Limit noted.

Date Reported : 10/17/2016



Project Manager : Wayne Bryce

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

Sample Information:

Type : Potable Water
 Origin: Distribution

LABORATORY RESULTS

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

Fort Ann CSD

1 Catherine St

Fort Ann, NY 12827

Attn To : Kevin Lovely

Federal ID :

Collected : 09/26/2016 5:00 AM Point No

Received : 09/27/2016 12:10 PM Location:

Collected By : CLIENT

Lab No. : 1610034-025

Client Sample ID. : B120 B

Analytical Method: E200.8 : IOC

Analyst: CM

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	* 320	*	1	ug/L	15	10/15/2016 6:07 PM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.

S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with * Exceed Regulatory Limit(s). Limit noted.

Date Reported : 10/17/2016



Project Manager : Wayne Bryce

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

Sample Information:

Type : Potable Water
 Origin: Distribution

LABORATORY RESULTS

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

Fort Ann CSD

1 Catherine St

Fort Ann, NY 12827

Attn To : Kevin Lovely

Federal ID :

Collected : 09/26/2016 5:03 AM Point No

Received : 09/27/2016 12:10 PM Location:

Collected By : CLIENT

Lab No. : 1610034-026

Client Sample ID. : NO A

Analytical Method: E200.8 : IOC

Analyst: CM

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	11		1	ug/L	15	10/15/2016 6:10 PM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.


S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with * Exceed Regulatory Limit(s). Limit noted.

Date Reported : 10/17/2016



Project Manager : Wayne Bryce

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

Sample Information:

Type : Potable Water
 Origin: Distribution

LABORATORY RESULTS

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

Fort Ann CSD

1 Catherine St

Fort Ann, NY 12827

Attn To : Kevin Lovely

Federal ID :

Collected : 09/26/2016 5:03 AM Point No

Received : 09/27/2016 12:10 PM Location:

Collected By : CLIENT

Lab No. : 1610034-027

Client Sample ID. : NO B

Analytical Method: E200.8 : IOC

Analyst: CM

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	3.8		1	ug/L	15	10/15/2016 6:13 PM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.

S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with * Exceed Regulatory Limit(s). Limit noted.

Date Reported : 10/17/2016



Project Manager : Wayne Bryce

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

Sample Information:

Type : Potable Water
 Origin: Distribution

LABORATORY RESULTS

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

Fort Ann CSD

1 Catherine St

Fort Ann, NY 12827

Attn To : Kevin Lovely

Federal ID :

Collected : 09/26/2016 5:04 AM Point No

Received : 09/27/2016 12:10 PM Location:

Collected By : CLIENT

Lab No. : 1610034-028

Client Sample ID. : NO C

Analytical Method: E200.8 : IOC

Analyst: CM

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	3.9		1	ug/L	15	10/15/2016 6:16 PM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.


S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with * Exceed Regulatory Limit(s). Limit noted.

Date Reported : 10/17/2016



Project Manager : Wayne Bryce

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

Sample Information:

Type : Potable Water
 Origin: Distribution

LABORATORY RESULTS

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

Fort Ann CSD

1 Catherine St

Fort Ann, NY 12827

Attn To : Kevin Lovely

Federal ID :

Collected : 09/26/2016 5:05 AM Point No

Received : 09/27/2016 12:10 PM Location:

Collected By : CLIENT

Lab No. : 1610034-029

Client Sample ID. : NO D

Analytical Method: E200.8 : IOC

Analyst: CM

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	6.2		1	ug/L	15	10/15/2016 6:19 PM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.

S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with * Exceed Regulatory Limit(s). Limit noted.

Date Reported : 10/17/2016



Project Manager : Wayne Bryce

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

Sample Information:

Type : Potable Water
 Origin: Distribution

LABORATORY RESULTS

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

Fort Ann CSD

1 Catherine St

Fort Ann, NY 12827

Attn To : Kevin Lovely

Federal ID :

Collected : 09/26/2016 5:07 AM Point No

Received : 09/27/2016 12:10 PM Location:

Collected By : CLIENT

Lab No. : 1610034-030

Client Sample ID. : B119 A

Analytical Method: E200.8 : IOC

Analyst: CM

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	11		1	ug/L	15	10/15/2016 6:22 PM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.


S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with * Exceed Regulatory Limit(s). Limit noted.

Date Reported : 10/17/2016



Project Manager : Wayne Bryce

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

Sample Information:

Type : Potable Water
 Origin: Distribution

LABORATORY RESULTS

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

Fort Ann CSD

1 Catherine St

Fort Ann, NY 12827

Attn To : Kevin Lovely

Federal ID :

Collected : 09/26/2016 5:07 AM Point No

Received : 09/27/2016 12:10 PM Location:

Collected By : CLIENT

Lab No. : 1610034-031

Client Sample ID. : B119 B

Analytical Method: E200.8 : IOC

Analyst: CM

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	* 65	*	1	ug/L	15	10/15/2016 6:25 PM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.


S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with * Exceed Regulatory Limit(s). Limit noted.

Date Reported : 10/17/2016



Project Manager : Wayne Bryce

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

Sample Information:

Type : Potable Water

Origin: Distribution

LABORATORY RESULTS

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

Fort Ann CSD

1 Catherine St

Fort Ann, NY 12827

Attn To : Kevin Lovely

Federal ID :

Collected : 09/26/2016 5:09 AM Point No

Received : 09/27/2016 12:10 PM Location:

Collected By : CLIENT

Lab No. : 1610034-032

Client Sample ID. : B109 A

Analytical Method: E200.8 : IOC

Analyst: CM

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	9.0		1	ug/L	15	10/15/2016 6:40 PM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.


S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with * Exceed Regulatory Limit(s). Limit noted.

Date Reported : 10/17/2016



Project Manager : Wayne Bryce

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

Sample Information:

Type : Potable Water
 Origin: Distribution

LABORATORY RESULTS

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

Fort Ann CSD

1 Catherine St

Fort Ann, NY 12827

Attn To : Kevin Lovely

Federal ID :

Collected : 09/26/2016 5:09 AM Point No

Received : 09/27/2016 12:10 PM Location:

Collected By : CLIENT

Lab No. : 1610034-033

Client Sample ID. : B109 B

Analytical Method: E200.8 : IOC

Analyst: CM

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	5.3		1	ug/L	15	10/15/2016 6:42 PM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.


S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with * Exceed Regulatory Limit(s). Limit noted.

Date Reported : 10/17/2016



Project Manager : Wayne Bryce

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

Sample Information:

Type : Potable Water
 Origin: Distribution

LABORATORY RESULTS

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

Fort Ann CSD

1 Catherine St

Fort Ann, NY 12827

Attn To : Kevin Lovely

Federal ID :

Collected : 09/26/2016 5:11 AM Point No

Received : 09/27/2016 12:10 PM Location:

Collected By : CLIENT

Lab No. : 1610034-034

Client Sample ID. : B108 A

Analytical Method: E200.8 : IOC

Analyst: CM

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	5.9		1	ug/L	15	10/15/2016 6:45 PM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.


S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with * Exceed Regulatory Limit(s). Limit noted.

Date Reported : 10/17/2016



Project Manager : Wayne Bryce

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

Sample Information:

Type : Potable Water
 Origin: Distribution

LABORATORY RESULTS

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

Fort Ann CSD

1 Catherine St

Fort Ann, NY 12827

Attn To : Kevin Lovely

Federal ID :

Collected : 09/26/2016 5:11 AM Point No

Received : 09/27/2016 12:10 PM Location:

Collected By : CLIENT

Lab No. : 1610034-035

Client Sample ID. : B108 B

Analytical Method: E200.8 : IOC

Analyst: CM

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	7.3		1	ug/L	15	10/15/2016 6:48 PM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.

S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with * Exceed Regulatory Limit(s). Limit noted.

Date Reported : 10/17/2016



Project Manager : Wayne Bryce

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

Sample Information:

Type : Potable Water

Origin: Distribution

LABORATORY RESULTS

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

Fort Ann CSD

1 Catherine St

Fort Ann, NY 12827

Attn To : Kevin Lovely

Federal ID :

Collected : 09/26/2016 5:14 AM Point No

Received : 09/27/2016 12:10 PM Location:

Collected By : CLIENT

Lab No. : 1610034-036

Client Sample ID. : B107 A

Analytical Method: E200.8 : IOC

Analyst: CM

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	9.5		1	ug/L	15	10/15/2016 6:51 PM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.


S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with * Exceed Regulatory Limit(s). Limit noted.

Date Reported : 10/17/2016



Project Manager : Wayne Bryce

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

Sample Information:

Type : Potable Water
 Origin: Distribution

LABORATORY RESULTS

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

Fort Ann CSD

1 Catherine St

Fort Ann, NY 12827

Attn To : Kevin Lovely

Federal ID :

Collected : 09/26/2016 5:14 AM Point No

Received : 09/27/2016 12:10 PM Location:

Collected By : CLIENT

Lab No. : 1610034-037

Client Sample ID. : B107 B

Analytical Method: E200.8 : IOC

Analyst: CM

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	* 21	*	1	ug/L	15	10/15/2016 6:54 PM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.

S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with * Exceed Regulatory Limit(s). Limit noted.

Date Reported : 10/17/2016



Project Manager : Wayne Bryce

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

Sample Information:

Type : Potable Water
 Origin: Distribution

LABORATORY RESULTS

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

Fort Ann CSD

1 Catherine St

Fort Ann, NY 12827

Attn To : Kevin Lovely

Federal ID :

Collected : 09/26/2016 5:17 AM Point No

Received : 09/27/2016 12:10 PM Location:

Collected By : CLIENT

Lab No. : 1610034-038

Client Sample ID. : B106 A

Analytical Method: E200.8 : IOC

Analyst: CM

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	13		1	ug/L	15	10/15/2016 6:57 PM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.


S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with * Exceed Regulatory Limit(s). Limit noted.

Date Reported : 10/17/2016



Project Manager : Wayne Bryce

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

Sample Information:

Type : Potable Water
 Origin: Distribution

LABORATORY RESULTS

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

Fort Ann CSD

1 Catherine St

Fort Ann, NY 12827

Attn To : Kevin Lovely

Federal ID :

Collected : 09/26/2016 5:17 AM Point No

Received : 09/27/2016 12:10 PM Location:

Collected By : CLIENT

Lab No. : 1610034-039

Client Sample ID. : B106 B

Analytical Method: E200.8 : IOC

Analyst: CM

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	* 25	*	1	ug/L	15	10/15/2016 7:00 PM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.


S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with * Exceed Regulatory Limit(s). Limit noted.

Date Reported : 10/17/2016



Project Manager : Wayne Bryce

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

Sample Information:

Type : Potable Water
 Origin: Distribution

LABORATORY RESULTS

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

Fort Ann CSD

1 Catherine St

Fort Ann, NY 12827

Attn To : Kevin Lovely

Federal ID :

Collected : 09/26/2016 5:19 AM Point No

Received : 09/27/2016 12:10 PM Location:

Collected By : CLIENT

Lab No. : 1610034-040

Client Sample ID. : B105 A

Analytical Method: E200.8 : IOC

Analyst: CM

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	8.0		1	ug/L	15	10/15/2016 7:15 PM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.


S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with * Exceed Regulatory Limit(s). Limit noted.

Date Reported : 10/17/2016



Project Manager : Wayne Bryce

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

Sample Information:

Type : Potable Water
 Origin: Distribution

LABORATORY RESULTS

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

Fort Ann CSD

1 Catherine St

Fort Ann, NY 12827

Attn To : Kevin Lovely

Federal ID :

Collected : 09/26/2016 5:19 AM Point No

Received : 09/27/2016 12:10 PM Location:

Collected By : CLIENT

Lab No. : 1610034-041

Client Sample ID. : B105 B

Analytical Method: E200.8 : IOC

Analyst: CM

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	* 28	*	1	ug/L	15	10/15/2016 7:17 PM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.


S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with * Exceed Regulatory Limit(s). Limit noted.

Date Reported : 10/17/2016



Project Manager : Wayne Bryce

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

Sample Information:

Type : Potable Water
 Origin: Distribution

LABORATORY RESULTS

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

Fort Ann CSD

1 Catherine St

Fort Ann, NY 12827

Attn To : Kevin Lovely

Federal ID :

Collected : 09/26/2016 5:21 AM Point No

Received : 09/27/2016 12:10 PM Location:

Collected By : CLIENT

Lab No. : 1610034-042

Client Sample ID. : B104 A

Analytical Method: E200.8 : IOC

Analyst: CM

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	* 19	*	1	ug/L	15	10/15/2016 7:20 PM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.

S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with * Exceed Regulatory Limit(s). Limit noted.

Date Reported : 10/17/2016



Project Manager : Wayne Bryce

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

Sample Information:

Type : Potable Water
 Origin: Distribution

LABORATORY RESULTS

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

Fort Ann CSD

1 Catherine St

Fort Ann, NY 12827

Attn To : Kevin Lovely

Federal ID :

Collected : 09/26/2016 5:21 AM Point No

Received : 09/27/2016 12:10 PM Location:

Collected By : CLIENT

Lab No. : 1610034-043

Client Sample ID. : B104 B

Analytical Method: E200.8 : IOC

Analyst: CM

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	* 19	*	1	ug/L	15	10/15/2016 7:23 PM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.

S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with * Exceed Regulatory Limit(s). Limit noted.

Date Reported : 10/17/2016



Project Manager : Wayne Bryce

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

Sample Information:

Type : Potable Water
 Origin: Distribution

LABORATORY RESULTS

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

Fort Ann CSD

1 Catherine St

Fort Ann, NY 12827

Attn To : Kevin Lovely

Federal ID :

Collected : 09/26/2016 5:22 AM Point No

Received : 09/27/2016 12:10 PM Location:

Collected By : CLIENT

Lab No. : 1610034-044

Client Sample ID. : PT 1

Analytical Method: E200.8 : IOC

Analyst: CM

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	12		1	ug/L	15	10/15/2016 7:26 PM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.


S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with * Exceed Regulatory Limit(s). Limit noted.

Date Reported : 10/17/2016



Project Manager : Wayne Bryce

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

Sample Information:

Type : Potable Water
 Origin: Distribution

LABORATORY RESULTS

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

Fort Ann CSD

1 Catherine St

Fort Ann, NY 12827

Attn To : Kevin Lovely

Federal ID :

Collected : 09/26/2016 5:23 AM Point No

Received : 09/27/2016 12:10 PM Location:

Collected By : CLIENT

Lab No. : 1610034-045

Client Sample ID. : TL 1

Analytical Method: E200.8 : IOC

Analyst: CM

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	5.5		1	ug/L	15	10/15/2016 7:29 PM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.

S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with * Exceed Regulatory Limit(s). Limit noted.

Date Reported : 10/17/2016



Project Manager : Wayne Bryce

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

Sample Information:

Type : Potable Water
 Origin: Distribution

LABORATORY RESULTS

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

Fort Ann CSD

1 Catherine St

Fort Ann, NY 12827

Attn To : Kevin Lovely

Federal ID :

Collected : 09/26/2016 5:25 AM Point No

Received : 09/27/2016 12:10 PM Location:

Collected By : CLIENT

Lab No. : 1610034-046

Client Sample ID. : B103 A

Analytical Method: E200.8 : IOC

Analyst: CM

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	* 21	*	1	ug/L	15	10/15/2016 7:32 PM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.


S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with * Exceed Regulatory Limit(s). Limit noted.

Date Reported : 10/17/2016



Project Manager : Wayne Bryce

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

Sample Information:

Type : Potable Water
 Origin: Distribution

LABORATORY RESULTS

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

Fort Ann CSD

1 Catherine St

Fort Ann, NY 12827

Attn To : Kevin Lovely

Federal ID :

Collected : 09/26/2016 5:25 AM Point No

Received : 09/27/2016 12:10 PM Location:

Collected By : CLIENT

Lab No. : 1610034-047

Client Sample ID. : B103 B

Analytical Method: E200.8 : IOC

Analyst: CM

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	* 49	*	1	ug/L	15	10/15/2016 7:35 PM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.


S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with * Exceed Regulatory Limit(s). Limit noted.

Date Reported : 10/17/2016



Project Manager : Wayne Bryce

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

Sample Information:

Type : Potable Water

Origin: Distribution

LABORATORY RESULTS

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

Fort Ann CSD

1 Catherine St

Fort Ann, NY 12827

Attn To : Kevin Lovely

Federal ID :

Collected : 09/26/2016 5:29 AM Point No

Received : 09/27/2016 12:10 PM Location:

Collected By : CLIENT

Lab No. : 1610034-048

Client Sample ID. : B102 A

Analytical Method: E200.8 : IOC

Analyst: CM

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	3.9		1	ug/L	15	10/15/2016 7:50 PM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.

S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with * Exceed Regulatory Limit(s). Limit noted.

Date Reported : 10/17/2016



Project Manager : Wayne Bryce

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

Sample Information:

Type : Potable Water
 Origin: Distribution

LABORATORY RESULTS

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

Fort Ann CSD

1 Catherine St

Fort Ann, NY 12827

Attn To : Kevin Lovely

Federal ID :

Collected : 09/26/2016 5:29 AM Point No

Received : 09/27/2016 12:10 PM Location:

Collected By : CLIENT

Lab No. : 1610034-049

Client Sample ID. : B102 B

Analytical Method: E200.8 : IOC

Analyst: CM

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	5.9		1	ug/L	15	10/15/2016 7:53 PM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.


S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with * Exceed Regulatory Limit(s). Limit noted.

Date Reported : 10/17/2016



Project Manager : Wayne Bryce

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

Sample Information:

Type : Potable Water
 Origin: Distribution

LABORATORY RESULTS

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

Fort Ann CSD

1 Catherine St

Fort Ann, NY 12827

Attn To : Kevin Lovely

Federal ID :

Collected : 09/26/2016 5:32 AM Point No

Received : 09/27/2016 12:10 PM Location:

Collected By : CLIENT

Lab No. : 1610034-050

Client Sample ID. : B101 A

Analytical Method: E200.8 : IOC

Analyst: CM

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	* 17	*	1	ug/L	15	10/15/2016 7:56 PM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.

S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with * Exceed Regulatory Limit(s). Limit noted.

Date Reported : 10/17/2016



Project Manager : Wayne Bryce

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

Sample Information:

Type : Potable Water
 Origin: Distribution

LABORATORY RESULTS

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

Fort Ann CSD

1 Catherine St

Fort Ann, NY 12827

Attn To : Kevin Lovely

Federal ID :

Collected : 09/26/2016 5:32 AM Point No

Received : 09/27/2016 12:10 PM Location:

Collected By : CLIENT

Lab No. : 1610034-051

Client Sample ID. : B101 B

Analytical Method: E200.8 : IOC

Analyst: CM

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	7.2		1	ug/L	15	10/15/2016 7:58 PM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.

S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with * Exceed Regulatory Limit(s). Limit noted.

Date Reported : 10/17/2016



Project Manager : Wayne Bryce

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

Sample Information:

Type : Potable Water
 Origin: Distribution

LABORATORY RESULTS

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

Fort Ann CSD

1 Catherine St

Fort Ann, NY 12827

Attn To : Kevin Lovely

Federal ID :

Collected : 09/26/2016 5:34 AM Point No

Received : 09/27/2016 12:10 PM Location:

Collected By : CLIENT

Lab No. : 1610034-052

Client Sample ID. : P1 A

Analytical Method: E200.8 : IOC

Analyst: CM

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	11		1	ug/L	15	10/15/2016 8:01 PM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.

S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with * Exceed Regulatory Limit(s). Limit noted.

Date Reported : 10/17/2016



Project Manager : Wayne Bryce

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

Sample Information:

Type : Potable Water
Origin: Distribution

LABORATORY RESULTS

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

Fort Ann CSD

1 Catherine St

Fort Ann, NY 12827

Attn To : Kevin Lovely

Federal ID :

Collected : 09/26/2016 5:34 AM Point No

Received : 09/27/2016 12:10 PM Location:

Collected By : CLIENT

Lab No. : 1610034-053

Client Sample ID. : P1 B

Analytical Method: E200.8 : IOC

Analyst: CM

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	5.7		1	ug/L	15	10/15/2016 8:04 PM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.

S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with * Exceed Regulatory Limit(s). Limit noted.

Date Reported : 10/17/2016



Project Manager : Wayne Bryce

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

Sample Information:

Type : Potable Water
 Origin: Distribution

LABORATORY RESULTS

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

Fort Ann CSD

1 Catherine St

Fort Ann, NY 12827

Attn To : Kevin Lovely

Federal ID :

Collected : 09/26/2016 5:37 AM Point No

Received : 09/27/2016 12:10 PM Location:

Collected By : CLIENT

Lab No. : 1610034-054

Client Sample ID. : B110 A

Analytical Method: E200.8 : IOC

Analyst: CM

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	5.6		1	ug/L	15	10/15/2016 8:07 PM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.


S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with * Exceed Regulatory Limit(s). Limit noted.

Date Reported : 10/17/2016



Project Manager : Wayne Bryce

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

Sample Information:

Type : Potable Water
Origin: Distribution

LABORATORY RESULTS

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

Fort Ann CSD

1 Catherine St

Fort Ann, NY 12827

Attn To : Kevin Lovely

Federal ID :

Collected : 09/26/2016 5:37 AM Point No

Received : 09/27/2016 12:10 PM Location:

Collected By : CLIENT

Lab No. : 1610034-055

Client Sample ID. : B110 B

Analytical Method: E200.8 : IOC

Analyst: CM

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	2.5		1	ug/L	15	10/15/2016 8:10 PM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.


S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with * Exceed Regulatory Limit(s). Limit noted.

Date Reported : 10/17/2016



Project Manager : Wayne Bryce

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

Sample Information:

Type : Potable Water
 Origin: Distribution

LABORATORY RESULTS

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

Fort Ann CSD

1 Catherine St

Fort Ann, NY 12827

Attn To : Kevin Lovely

Federal ID :

Collected : 09/26/2016 5:37 AM Point No

Received : 09/27/2016 12:10 PM Location:

Collected By : CLIENT

Lab No. : 1610034-056

Client Sample ID. : B110 C

Analytical Method: E200.8 : IOC

Analyst: CM

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	11		1	ug/L	15	10/15/2016 8:25 PM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.


S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with * Exceed Regulatory Limit(s). Limit noted.

Date Reported : 10/17/2016



Project Manager : Wayne Bryce

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

Sample Information:

Type : Potable Water
 Origin: Distribution

LABORATORY RESULTS

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

Fort Ann CSD

1 Catherine St

Fort Ann, NY 12827

Attn To : Kevin Lovely

Federal ID :

Collected : 09/26/2016 5:40 AM Point No

Received : 09/27/2016 12:10 PM Location:

Collected By : CLIENT

Lab No. : 1610034-057

Client Sample ID. : B111 A

Analytical Method: E200.8 : IOC

Analyst: CM

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	5.6		1	ug/L	15	10/15/2016 8:28 PM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.


S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with * Exceed Regulatory Limit(s). Limit noted.

Date Reported : 10/17/2016



Project Manager : Wayne Bryce

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

Sample Information:

Type : Potable Water
 Origin: Distribution

LABORATORY RESULTS

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

Fort Ann CSD

1 Catherine St

Fort Ann, NY 12827

Attn To : Kevin Lovely

Federal ID :

Collected : 09/26/2016 5:40 AM Point No

Received : 09/27/2016 12:10 PM Location:

Collected By : CLIENT

Lab No. : 1610034-058

Client Sample ID. : B111 B

Analytical Method: E200.8 : IOC

Analyst: CM

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	2.4		1	ug/L	15	10/15/2016 8:31 PM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.


S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with * Exceed Regulatory Limit(s). Limit noted.

Date Reported : 10/17/2016



Project Manager : Wayne Bryce

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

Sample Information:

Type : Potable Water
 Origin: Distribution

LABORATORY RESULTS

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

Fort Ann CSD

1 Catherine St

Fort Ann, NY 12827

Attn To : Kevin Lovely

Federal ID :

Collected : 09/26/2016 5:40 AM Point No

Received : 09/27/2016 12:10 PM Location:

Collected By : CLIENT

Lab No. : 1610034-059

Client Sample ID. : B111 C

Analytical Method: E200.8 : IOC

Analyst: CM

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	3.1		1	ug/L	15	10/15/2016 8:33 PM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.

S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with * Exceed Regulatory Limit(s). Limit noted.

Date Reported : 10/17/2016



Project Manager : Wayne Bryce

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

Sample Information:

Type : Potable Water

Origin: Distribution

LABORATORY RESULTS

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

Fort Ann CSD

1 Catherine St

Fort Ann, NY 12827

Attn To : Kevin Lovely

Federal ID :

Collected : 09/26/2016 5:44 AM Point No

Received : 09/27/2016 12:10 PM Location:

Collected By : CLIENT

Lab No. : 1610034-060

Client Sample ID. : A112 A

Analytical Method: E200.8 : IOC

Analyst: CM

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	7.9		1	ug/L	15	10/15/2016 8:36 PM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.


S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with * Exceed Regulatory Limit(s). Limit noted.

Date Reported : 10/17/2016



Project Manager : Wayne Bryce

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

Sample Information:

Type : Potable Water

Origin: Distribution

LABORATORY RESULTS

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

Fort Ann CSD

1 Catherine St

Fort Ann, NY 12827

Attn To : Kevin Lovely

Federal ID :

Collected : 09/26/2016 5:45 AM Point No

Received : 09/27/2016 12:10 PM Location:

Collected By : CLIENT

Lab No. : 1610034-061

Client Sample ID. : B112 A

Analytical Method: E200.8 : IOC

Analyst: CM

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	4.3		1	ug/L	15	10/15/2016 8:39 PM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.

S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with * Exceed Regulatory Limit(s). Limit noted.

Date Reported : 10/17/2016



Project Manager : Wayne Bryce

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

Sample Information:

Type : Potable Water

Origin: Distribution

LABORATORY RESULTS

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

Fort Ann CSD

1 Catherine St

Fort Ann, NY 12827

Attn To : Kevin Lovely

Federal ID :

Collected : 09/26/2016 5:45 AM Point No

Received : 09/27/2016 12:10 PM Location:

Collected By : CLIENT

Lab No. : 1610034-062

Client Sample ID. : B112 B

Analytical Method: E200.8 : IOC

Analyst: CM

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	< 1.0		1	ug/L	15	10/15/2016 8:42 PM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.


S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with * Exceed Regulatory Limit(s). Limit noted.

Date Reported : 10/17/2016



Project Manager : Wayne Bryce

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

Sample Information:

Type : Potable Water
Origin: Distribution

LABORATORY RESULTS

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

Fort Ann CSD

1 Catherine St

Fort Ann, NY 12827

Attn To : Kevin Lovely

Federal ID :

Collected : 09/26/2016 5:45 AM Point No

Received : 09/27/2016 12:10 PM Location:

Collected By : CLIENT

Lab No. : 1610034-063

Client Sample ID. : B112 C

Analytical Method: E200.8 : IOC

Analyst: CM

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	1.7		1	ug/L	15	10/15/2016 8:45 PM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.

S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with * Exceed Regulatory Limit(s). Limit noted.

Date Reported : 10/17/2016



Project Manager : Wayne Bryce

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

Sample Information:

Type : Potable Water
 Origin: Distribution

LABORATORY RESULTS

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

Fort Ann CSD

1 Catherine St

Fort Ann, NY 12827

Attn To : Kevin Lovely

Federal ID :

Collected : 09/26/2016 5:49 AM Point No

Received : 09/27/2016 12:10 PM Location:

Collected By : CLIENT

Lab No. : 1610034-064

Client Sample ID. : BR6 A

Analytical Method: E200.8 : IOC

Analyst: CM

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	4.7		1	ug/L	15	10/15/2016 9:00 PM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.


S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with * Exceed Regulatory Limit(s). Limit noted.

Date Reported : 10/17/2016



Project Manager : Wayne Bryce

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

Sample Information:

Type : Potable Water
Origin: Distribution

LABORATORY RESULTS

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

Fort Ann CSD

1 Catherine St

Fort Ann, NY 12827

Attn To : Kevin Lovely

Federal ID :

Collected : 09/26/2016 5:49 AM Point No

Received : 09/27/2016 12:10 PM Location:

Collected By : CLIENT

Lab No. : 1610034-065

Client Sample ID. : BR6 B

Analytical Method: E200.8 : IOC

Analyst: CM

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	3.9		1	ug/L	15	10/15/2016 9:03 PM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.

S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with * Exceed Regulatory Limit(s). Limit noted.

Date Reported : 10/17/2016



Project Manager : Wayne Bryce

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

Sample Information:

Type : Potable Water
 Origin: Distribution

LABORATORY RESULTS

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

Fort Ann CSD

1 Catherine St

Fort Ann, NY 12827

Attn To : Kevin Lovely

Federal ID :

Collected : 09/26/2016 5:49 AM Point No

Received : 09/27/2016 12:10 PM Location:

Collected By : CLIENT

Lab No. : 1610034-066

Client Sample ID. : BR6 C

Analytical Method: E200.8 : IOC

Analyst: CM

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	1.8		1	ug/L	15	10/15/2016 9:06 PM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.


S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with * Exceed Regulatory Limit(s). Limit noted.

Date Reported : 10/17/2016



Project Manager : Wayne Bryce

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

Sample Information:

Type : Potable Water

Origin: Distribution

LABORATORY RESULTS

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

Fort Ann CSD

1 Catherine St

Fort Ann, NY 12827

Attn To : Kevin Lovely

Federal ID :

Collected : 09/26/2016 5:51 AM Point No

Received : 09/27/2016 12:10 PM Location:

Collected By : CLIENT

Lab No. : 1610034-067

Client Sample ID. : C1 A

Analytical Method: E200.8 : IOC

Analyst: CM

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	3.0		1	ug/L	15	10/15/2016 9:09 PM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.

S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with * Exceed Regulatory Limit(s). Limit noted.

Date Reported : 10/17/2016



Project Manager : Wayne Bryce

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

Sample Information:

Type : Potable Water
 Origin: Distribution

LABORATORY RESULTS

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

Fort Ann CSD

1 Catherine St

Fort Ann, NY 12827

Attn To : Kevin Lovely

Federal ID :

Collected : 09/26/2016 5:53 AM Point No

Received : 09/27/2016 12:10 PM Location:

Collected By : CLIENT

Lab No. : 1610034-068

Client Sample ID. : BR7 A

Analytical Method: E200.8 : IOC

Analyst: CM

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	* 24	*	1	ug/L	15	10/15/2016 9:12 PM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.


S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with * Exceed Regulatory Limit(s). Limit noted.

Date Reported : 10/17/2016



Project Manager : Wayne Bryce

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

Sample Information:

Type : Potable Water
 Origin: Distribution

LABORATORY RESULTS

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

Fort Ann CSD

1 Catherine St

Fort Ann, NY 12827

Attn To : Kevin Lovely

Federal ID :

Collected : 09/26/2016 5:53 AM Point No

Received : 09/27/2016 12:10 PM Location:

Collected By : CLIENT

Lab No. : 1610034-069

Client Sample ID. : BR7 B

Analytical Method: E200.8 : IOC

Analyst: CM

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	2.1		1	ug/L	15	10/15/2016 9:14 PM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.

S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with * Exceed Regulatory Limit(s). Limit noted.

Date Reported : 10/17/2016



Project Manager : Wayne Bryce

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

Sample Information:

Type : Potable Water
 Origin: Distribution

LABORATORY RESULTS

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

Fort Ann CSD

1 Catherine St

Fort Ann, NY 12827

Attn To : Kevin Lovely

Federal ID :

Collected : 09/26/2016 5:53 AM Point No

Received : 09/27/2016 12:10 PM Location:

Collected By : CLIENT

Lab No. : 1610034-070

Client Sample ID. : BR7 C

Analytical Method: E200.8 : IOC

Analyst: CM

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	4.6		1	ug/L	15	10/15/2016 9:17 PM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.


S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with * Exceed Regulatory Limit(s). Limit noted.

Date Reported : 10/17/2016



Project Manager : Wayne Bryce

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

Sample Information:

Type : Potable Water
 Origin: Distribution

LABORATORY RESULTS

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

Fort Ann CSD

1 Catherine St

Fort Ann, NY 12827

Attn To : Kevin Lovely

Federal ID :

Collected : 09/26/2016 5:55 AM Point No

Received : 09/27/2016 12:10 PM Location:

Collected By : CLIENT

Lab No. : 1610034-071

Client Sample ID. : B113 A

Analytical Method: E200.8 : IOC

Analyst: CM

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	7.0		1	ug/L	15	10/15/2016 9:20 PM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.


S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with * Exceed Regulatory Limit(s). Limit noted.

Date Reported : 10/17/2016



Project Manager : Wayne Bryce

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

Sample Information:

Type : Potable Water
 Origin: Distribution

LABORATORY RESULTS

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

Fort Ann CSD

1 Catherine St

Fort Ann, NY 12827

Attn To : Kevin Lovely

Federal ID :

Collected : 09/26/2016 5:55 AM Point No

Received : 09/27/2016 12:10 PM Location:

Collected By : CLIENT

Lab No. : 1610034-072

Client Sample ID. : B113 B

Analytical Method: E200.8 : IOC

Analyst: CM

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	1.7		1	ug/L	15	10/15/2016 9:35 PM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.


S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with * Exceed Regulatory Limit(s). Limit noted.

Date Reported : 10/17/2016



Project Manager : Wayne Bryce

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

Sample Information:

Type : Potable Water
 Origin: Distribution

LABORATORY RESULTS

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

Fort Ann CSD

1 Catherine St

Fort Ann, NY 12827

Attn To : Kevin Lovely

Federal ID :

Collected : 09/26/2016 6:00 AM Point No

Received : 09/27/2016 12:10 PM Location:

Collected By : CLIENT

Lab No. : 1610034-073

Client Sample ID. : B114 A

Analytical Method: E200.8 : IOC

Analyst: CM

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	4.7		1	ug/L	15	10/15/2016 9:38 PM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.


S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with * Exceed Regulatory Limit(s). Limit noted.

Date Reported : 10/17/2016



Project Manager : Wayne Bryce

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

Sample Information:

Type : Potable Water
 Origin: Distribution

LABORATORY RESULTS

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

Fort Ann CSD

1 Catherine St

Fort Ann, NY 12827

Attn To : Kevin Lovely

Federal ID :

Collected : 09/26/2016 6:00 AM Point No

Received : 09/27/2016 12:10 PM Location:

Collected By : CLIENT

Lab No. : 1610034-074

Client Sample ID. : B114 B

Analytical Method: E200.8 : IOC

Analyst: CM

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	4.4		1	ug/L	15	10/15/2016 9:41 PM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.


S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with * Exceed Regulatory Limit(s). Limit noted.

Date Reported : 10/17/2016



Project Manager : Wayne Bryce

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

Sample Information:

Type : Potable Water
 Origin: Distribution

LABORATORY RESULTS

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

Fort Ann CSD

1 Catherine St

Fort Ann, NY 12827

Attn To : Kevin Lovely

Federal ID :

Collected : 09/26/2016 6:03 AM Point No

Received : 09/27/2016 12:10 PM Location:

Collected By : CLIENT

Lab No. : 1610034-075

Client Sample ID. : B115 A

Analytical Method: E200.8 : IOC

Analyst: CM

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	6.5		1	ug/L	15	10/15/2016 9:44 PM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.

S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with * Exceed Regulatory Limit(s). Limit noted.

Date Reported : 10/17/2016



Project Manager : Wayne Bryce

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

Sample Information:

Type : Potable Water
 Origin: Distribution

LABORATORY RESULTS

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

Fort Ann CSD

1 Catherine St

Fort Ann, NY 12827

Attn To : Kevin Lovely

Federal ID :

Collected : 09/26/2016 6:03 AM Point No

Received : 09/27/2016 12:10 PM Location:

Collected By : CLIENT

Lab No. : 1610034-076

Client Sample ID. : B115 B

Analytical Method: E200.8 : IOC

Analyst: CM

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	2.7		1	ug/L	15	10/15/2016 9:47 PM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.


S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with * Exceed Regulatory Limit(s). Limit noted.

Date Reported : 10/17/2016



Project Manager : Wayne Bryce

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

Sample Information:

Type : Potable Water
 Origin: Distribution

LABORATORY RESULTS

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

Fort Ann CSD

1 Catherine St

Fort Ann, NY 12827

Attn To : Kevin Lovely

Federal ID :

Collected : 09/26/2016 6:04 AM Point No

Received : 09/27/2016 12:10 PM Location:

Collected By : CLIENT

Lab No. : 1610034-077

Client Sample ID. : B116 A

Analytical Method: E200.8 : IOC

Analyst: CM

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	4.9		1	ug/L	15	10/15/2016 9:50 PM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.

S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with * Exceed Regulatory Limit(s). Limit noted.

Date Reported : 10/17/2016



Project Manager : Wayne Bryce

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

Sample Information:

Type : Potable Water

Origin: Distribution

LABORATORY RESULTS

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

Fort Ann CSD

1 Catherine St

Fort Ann, NY 12827

Attn To : Kevin Lovely

Federal ID :

Collected : 09/26/2016 6:04 AM Point No

Received : 09/27/2016 12:10 PM Location:

Collected By : CLIENT

Lab No. : 1610034-078

Client Sample ID. : B116 B

Analytical Method: E200.8 : IOC

Analyst: CM

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	1.3		1	ug/L	15	10/15/2016 9:52 PM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.


S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with * Exceed Regulatory Limit(s). Limit noted.

Date Reported : 10/17/2016



Project Manager : Wayne Bryce

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

Sample Information:

Type : Potable Water
 Origin: Distribution

LABORATORY RESULTS

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

Fort Ann CSD

1 Catherine St

Fort Ann, NY 12827

Attn To : Kevin Lovely

Federal ID :

Collected : 09/26/2016 6:05 AM Point No

Received : 09/27/2016 12:10 PM Location:

Collected By : CLIENT

Lab No. : 1610034-079

Client Sample ID. : B117 A

Analytical Method: E200.8 : IOC

Analyst: CM

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	6.9		1	ug/L	15	10/15/2016 9:55 PM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.


S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with * Exceed Regulatory Limit(s). Limit noted.

Date Reported : 10/17/2016



Project Manager : Wayne Bryce

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

Sample Information:

Type : Potable Water
 Origin: Distribution

LABORATORY RESULTS

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

Fort Ann CSD

1 Catherine St

Fort Ann, NY 12827

Attn To : Kevin Lovely

Federal ID :

Collected : 09/26/2016 6:05 AM Point No

Received : 09/27/2016 12:10 PM Location:

Collected By : CLIENT

Lab No. : 1610034-080

Client Sample ID. : B117 B

Analytical Method: E200.8 : IOC

Analyst: CM

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	2.8		1	ug/L	15	10/15/2016 10:10 PM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.


S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with * Exceed Regulatory Limit(s). Limit noted.

Date Reported : 10/17/2016



Project Manager : Wayne Bryce

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

Sample Information:

Type : Potable Water
 Origin: Distribution

LABORATORY RESULTS

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

Fort Ann CSD

1 Catherine St

Fort Ann, NY 12827

Attn To : Kevin Lovely

Federal ID :

Collected : 09/26/2016 6:07 AM Point No

Received : 09/27/2016 12:10 PM Location:

Collected By : CLIENT

Lab No. : 1610034-081

Client Sample ID. : B118 A

Analytical Method: E200.8 : IOC

Analyst: CM

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	4.2		1	ug/L	15	10/15/2016 10:13 PM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.


S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with * Exceed Regulatory Limit(s). Limit noted.

Date Reported : 10/17/2016



Project Manager : Wayne Bryce

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

Sample Information:

Type : Potable Water
 Origin: Distribution

LABORATORY RESULTS

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

Fort Ann CSD

1 Catherine St

Fort Ann, NY 12827

Attn To : Kevin Lovely

Federal ID :

Collected : 09/26/2016 6:07 AM Point No

Received : 09/27/2016 12:10 PM Location:

Collected By : CLIENT

Lab No. : 1610034-082

Client Sample ID. : B118 B

Analytical Method: E200.8 : IOC

Analyst: CM

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	5.2		1	ug/L	15	10/15/2016 10:16 PM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.


S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with * Exceed Regulatory Limit(s). Limit noted.

Date Reported : 10/17/2016



Project Manager : Wayne Bryce

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

Sample Information:

Type : Potable Water
 Origin: Distribution

LABORATORY RESULTS

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

Fort Ann CSD

1 Catherine St

Fort Ann, NY 12827

Attn To : Kevin Lovely

Federal ID :

Collected : 09/26/2016 6:07 AM Point No

Received : 09/27/2016 12:10 PM Location:

Collected By : CLIENT

Lab No. : 1610034-083

Client Sample ID. : B118 C

Analytical Method: E200.8 : IOC

Analyst: CM

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	4.8		1	ug/L	15	10/15/2016 10:19 PM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.

S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with * Exceed Regulatory Limit(s). Limit noted.

Date Reported : 10/17/2016



Project Manager : Wayne Bryce

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

Sample Information:

Type : Potable Water
 Origin: Distribution

LABORATORY RESULTS

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

Fort Ann CSD

1 Catherine St

Fort Ann, NY 12827

Attn To : Kevin Lovely

Federal ID :

Collected : 09/26/2016 6:07 AM Point No

Received : 09/27/2016 12:10 PM Location:

Collected By : CLIENT

Lab No. : 1610034-084

Client Sample ID. : B118 D

Analytical Method: E200.8 : IOC

Analyst: CM

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	4.5		1	ug/L	15	10/15/2016 10:22 PM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.


S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with * Exceed Regulatory Limit(s). Limit noted.

Date Reported : 10/17/2016



Project Manager : Wayne Bryce

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

Sample Information:

Type : Potable Water
 Origin: Distribution

LABORATORY RESULTS

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

Fort Ann CSD

1 Catherine St

Fort Ann, NY 12827

Attn To : Kevin Lovely

Federal ID :

Collected : 09/26/2016 6:11 AM Point No

Received : 09/27/2016 12:10 PM Location:

Collected By : CLIENT

Lab No. : 1610034-085

Client Sample ID. : A113 A

Analytical Method: E200.8 : IOC

Analyst: CM

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	< 1.0		1	ug/L	15	10/15/2016 10:25 PM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.

S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with * Exceed Regulatory Limit(s). Limit noted.

Date Reported : 10/17/2016



Project Manager : Wayne Bryce

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

Sample Information:

Type : Potable Water
 Origin: Distribution

LABORATORY RESULTS

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

Fort Ann CSD

1 Catherine St

Fort Ann, NY 12827

Attn To : Kevin Lovely

Federal ID :

Collected : 09/26/2016 6:11 AM Point No

Received : 09/27/2016 12:10 PM Location:

Collected By : CLIENT

Lab No. : 1610034-086

Client Sample ID. : A113 B

Analytical Method: E200.8 : IOC

Analyst: CM

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	< 1.0		1	ug/L	15	10/15/2016 10:28 PM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.


S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with * Exceed Regulatory Limit(s). Limit noted.

Date Reported : 10/17/2016



Project Manager : Wayne Bryce

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

Sample Information:

Type : Potable Water
 Origin: Distribution

LABORATORY RESULTS

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

Fort Ann CSD

1 Catherine St

Fort Ann, NY 12827

Attn To : Kevin Lovely

Federal ID :

Collected : 09/26/2016 6:11 AM Point No

Received : 09/27/2016 12:10 PM Location:

Collected By : CLIENT

Lab No. : 1610034-087

Client Sample ID. : A113 C

Analytical Method: E200.8 : IOC

Analyst: CM

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	1.8		1	ug/L	15	10/15/2016 10:30 PM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.


S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with * Exceed Regulatory Limit(s). Limit noted.

Date Reported : 10/17/2016



Project Manager : Wayne Bryce

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

Sample Information:

Type : Potable Water
 Origin: Distribution

LABORATORY RESULTS

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

Fort Ann CSD

1 Catherine St

Fort Ann, NY 12827

Attn To : Kevin Lovely

Federal ID :

Collected : 09/26/2016 6:14 AM Point No

Received : 09/27/2016 12:10 PM Location:

Collected By : CLIENT

Lab No. : 1610034-088

Client Sample ID. : A114 A

Analytical Method: E200.8 : IOC

Analyst: CM

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	3.5		1	ug/L	15	10/15/2016 10:45 PM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.


S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with * Exceed Regulatory Limit(s). Limit noted.

Date Reported : 10/17/2016



Project Manager : Wayne Bryce

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

Sample Information:

Type : Potable Water
 Origin: Distribution

LABORATORY RESULTS

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

Fort Ann CSD

1 Catherine St

Fort Ann, NY 12827

Attn To : Kevin Lovely

Federal ID :

Collected : 09/26/2016 6:15 AM Point No

Received : 09/27/2016 12:10 PM Location:

Collected By : CLIENT

Lab No. : 1610034-089

Client Sample ID. : A115 A

Analytical Method: E200.8 : IOC

Analyst: CM

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	* 24	*	1	ug/L	15	10/15/2016 10:48 PM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.


S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with * Exceed Regulatory Limit(s). Limit noted.

Date Reported : 10/17/2016



Project Manager : Wayne Bryce

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

Sample Information:

Type : Potable Water
 Origin: Distribution

LABORATORY RESULTS

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

Fort Ann CSD

1 Catherine St

Fort Ann, NY 12827

Attn To : Kevin Lovely

Federal ID :

Collected : 09/26/2016 6:15 AM Point No

Received : 09/27/2016 12:10 PM Location:

Collected By : CLIENT

Lab No. : 1610034-090

Client Sample ID. : A115 B

Analytical Method: E200.8 : IOC

Analyst: CM

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	4.5		1	ug/L	15	10/15/2016 10:51 PM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.


S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with * Exceed Regulatory Limit(s). Limit noted.

Date Reported : 10/17/2016



Project Manager : Wayne Bryce

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

Sample Information:

Type : Potable Water
 Origin: Distribution

LABORATORY RESULTS

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

Fort Ann CSD

1 Catherine St

Fort Ann, NY 12827

Attn To : Kevin Lovely

Federal ID :

Collected : 09/26/2016 6:18 AM Point No

Received : 09/27/2016 12:10 PM Location:

Collected By : CLIENT

Lab No. : 1610034-091

Client Sample ID. : HF 3A

Analytical Method: E200.8 : IOC

Analyst: CM

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	< 1.0		1	ug/L	15	10/15/2016 10:54 PM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.

S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with * Exceed Regulatory Limit(s). Limit noted.

Date Reported : 10/17/2016



Project Manager : Wayne Bryce

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

Sample Information:

Type : Potable Water
 Origin: Distribution

LABORATORY RESULTS

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

Fort Ann CSD

1 Catherine St

Fort Ann, NY 12827

Attn To : Kevin Lovely

Federal ID :

Collected : 09/26/2016 6:18 AM Point No

Received : 09/27/2016 12:10 PM Location:

Collected By : CLIENT

Lab No. : 1610034-092

Client Sample ID. : HF 3B

Analytical Method: E200.8 : IOC

Analyst: CM

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	< 1.0		1	ug/L	15	10/15/2016 10:57 PM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.


S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with * Exceed Regulatory Limit(s). Limit noted.

Date Reported : 10/17/2016



Project Manager : Wayne Bryce

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

Sample Information:

Type : Potable Water
 Origin: Distribution

LABORATORY RESULTS

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

Fort Ann CSD

1 Catherine St

Fort Ann, NY 12827

Attn To : Kevin Lovely

Federal ID :

Collected : 09/26/2016 6:19 AM Point No

Received : 09/27/2016 12:10 PM Location:

Collected By : CLIENT

Lab No. : 1610034-093

Client Sample ID. : A110 A

Analytical Method: E200.8 : IOC

Analyst: CM

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	5.5		1	ug/L	15	10/15/2016 11:00 PM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.

S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with * Exceed Regulatory Limit(s). Limit noted.

Date Reported : 10/17/2016



Project Manager : Wayne Bryce

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

Sample Information:

Type : Potable Water
 Origin: Distribution

LABORATORY RESULTS

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

Fort Ann CSD

1 Catherine St

Fort Ann, NY 12827

Attn To : Kevin Lovely

Federal ID :

Collected : 09/26/2016 6:22 AM Point No

Received : 09/27/2016 12:10 PM Location:

Collected By : CLIENT

Lab No. : 1610034-094

Client Sample ID. : A117 A

Analytical Method: E200.8 : IOC

Analyst: CM

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	2.0		1	ug/L	15	10/15/2016 11:03 PM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.


S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with * Exceed Regulatory Limit(s). Limit noted.

Date Reported : 10/17/2016



Project Manager : Wayne Bryce

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

Sample Information:

Type : Potable Water
 Origin: Distribution

LABORATORY RESULTS

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

Fort Ann CSD

1 Catherine St

Fort Ann, NY 12827

Attn To : Kevin Lovely

Federal ID :

Collected : 09/26/2016 6:22 AM Point No

Received : 09/27/2016 12:10 PM Location:

Collected By : CLIENT

Lab No. : 1610034-095

Client Sample ID. : A117 B

Analytical Method: E200.8 : IOC

Analyst: CM

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	2.7		1	ug/L	15	10/15/2016 11:06 PM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.


S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with * Exceed Regulatory Limit(s). Limit noted.

Date Reported : 10/17/2016



Project Manager : Wayne Bryce

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

Sample Information:

Type : Potable Water
Origin: Distribution

LABORATORY RESULTS

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

Fort Ann CSD

1 Catherine St

Fort Ann, NY 12827

Attn To : Kevin Lovely

Federal ID :

Collected : 09/26/2016 6:22 AM Point No

Received : 09/27/2016 12:10 PM Location:

Collected By : CLIENT

Lab No. : 1610034-096

Client Sample ID. : A117 C

Analytical Method: E200.8 : IOC

Analyst: CM

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	2.0		1	ug/L	15	10/16/2016 12:05 AM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.

S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with * Exceed Regulatory Limit(s). Limit noted.

Date Reported : 10/17/2016



Project Manager : Wayne Bryce

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

Sample Information:

Type : Potable Water
 Origin: Distribution

LABORATORY RESULTS

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

Fort Ann CSD

1 Catherine St

Fort Ann, NY 12827

Attn To : Kevin Lovely

Federal ID :

Collected : 09/26/2016 6:29 AM Point No

Received : 09/27/2016 12:10 PM Location:

Collected By : CLIENT

Lab No. : 1610034-097

Client Sample ID. : A118 A

Analytical Method: E200.8 : IOC

Analyst: CM

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	2.8		1	ug/L	15	10/16/2016 12:08 AM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.


S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with * Exceed Regulatory Limit(s). Limit noted.

Date Reported : 10/17/2016



Project Manager : Wayne Bryce

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

Sample Information:

Type : Potable Water
 Origin: Distribution

LABORATORY RESULTS

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

Fort Ann CSD

1 Catherine St

Fort Ann, NY 12827

Attn To : Kevin Lovely

Federal ID :

Collected : 09/26/2016 6:29 AM Point No

Received : 09/27/2016 12:10 PM Location:

Collected By : CLIENT

Lab No. : 1610034-098

Client Sample ID. : A118 B

Analytical Method: E200.8 : IOC

Analyst: CM

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	5.2		1	ug/L	15	10/16/2016 12:11 AM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.


S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with * Exceed Regulatory Limit(s). Limit noted.

Date Reported : 10/17/2016



Project Manager : Wayne Bryce

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

Sample Information:

Type : Potable Water
 Origin: Distribution

LABORATORY RESULTS

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

Fort Ann CSD

1 Catherine St

Fort Ann, NY 12827

Attn To : Kevin Lovely

Federal ID :

Collected : 09/26/2016 6:29 AM Point No

Received : 09/27/2016 12:10 PM Location:

Collected By : CLIENT

Lab No. : 1610034-099

Client Sample ID. : A118 C

Analytical Method: E200.8 : IOC

Analyst: CM

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	* 20	*	1	ug/L	15	10/16/2016 12:14 AM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.

S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with * Exceed Regulatory Limit(s). Limit noted.

Date Reported : 10/17/2016



Project Manager : Wayne Bryce

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

Sample Information:

Type : Potable Water
 Origin: Distribution

LABORATORY RESULTS

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

Fort Ann CSD

1 Catherine St

Fort Ann, NY 12827

Attn To : Kevin Lovely

Federal ID :

Collected : 09/26/2016 6:32 AM Point No

Received : 09/27/2016 12:10 PM Location:

Collected By : CLIENT

Lab No. : 1610034-100

Client Sample ID. : HF 4A

Analytical Method: E200.8 : IOC

Analyst: CM

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	1.8		1	ug/L	15	10/16/2016 12:17 AM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.


S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with * Exceed Regulatory Limit(s). Limit noted.

Date Reported : 10/17/2016



Project Manager : Wayne Bryce

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

Sample Information:

Type : Potable Water
 Origin: Distribution

LABORATORY RESULTS

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

Fort Ann CSD

1 Catherine St

Fort Ann, NY 12827

Attn To : Kevin Lovely

Federal ID :

Collected : 09/26/2016 6:32 AM Point No

Received : 09/27/2016 12:10 PM Location:

Collected By : CLIENT

Lab No. : 1610034-101

Client Sample ID. : HF 4B

Analytical Method: E200.8 : IOC

Analyst: CM

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	1.7		1	ug/L	15	10/16/2016 12:20 AM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.

S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with * Exceed Regulatory Limit(s). Limit noted.

Date Reported : 10/17/2016



Project Manager : Wayne Bryce

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

Sample Information:

Type : Potable Water
 Origin: Distribution

LABORATORY RESULTS

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

Fort Ann CSD

1 Catherine St

Fort Ann, NY 12827

Attn To : Kevin Lovely

Federal ID :

Collected : 09/26/2016 6:33 AM Point No

Received : 09/27/2016 12:10 PM Location:

Collected By : CLIENT

Lab No. : 1610034-102

Client Sample ID. : BR 9A

Analytical Method: E200.8 : IOC

Analyst: CM

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	15		1	ug/L	15	10/16/2016 12:23 AM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.


S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with * Exceed Regulatory Limit(s). Limit noted.

Date Reported : 10/17/2016



Project Manager : Wayne Bryce

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

Sample Information:

Type : Potable Water
Origin: Distribution

LABORATORY RESULTS

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

Fort Ann CSD

1 Catherine St

Fort Ann, NY 12827

Attn To : Kevin Lovely

Federal ID :

Collected : 09/26/2016 6:33 AM Point No

Received : 09/27/2016 12:10 PM Location:

Collected By : CLIENT

Lab No. : 1610034-103

Client Sample ID. : BR 9B

Analytical Method: E200.8 : IOC

Analyst: CM

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	13		1	ug/L	15	10/16/2016 12:26 AM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.

S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with * Exceed Regulatory Limit(s). Limit noted.

Date Reported : 10/17/2016



Project Manager : Wayne Bryce

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

Sample Information:

Type : Potable Water
 Origin: Distribution

LABORATORY RESULTS

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

Fort Ann CSD

1 Catherine St

Fort Ann, NY 12827

Attn To : Kevin Lovely

Federal ID :

Collected : 09/26/2016 6:35 AM Point No

Received : 09/27/2016 12:10 PM Location:

Collected By : CLIENT

Lab No. : 1610034-104

Client Sample ID. : BR 8A

Analytical Method: E200.8 : IOC

Analyst: CM

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	7.8		1	ug/L	15	10/16/2016 12:40 AM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.


S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with * Exceed Regulatory Limit(s). Limit noted.

Date Reported : 10/17/2016



Project Manager : Wayne Bryce

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

Sample Information:

Type : Potable Water

Origin: Distribution

LABORATORY RESULTS

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

Fort Ann CSD

1 Catherine St

Fort Ann, NY 12827

Attn To : Kevin Lovely

Federal ID :

Collected : 09/26/2016 6:35 AM Point No

Received : 09/27/2016 12:10 PM Location:

Collected By : CLIENT

Lab No. : 1610034-105

Client Sample ID. : BR 8B

Analytical Method: E200.8 : IOC

Analyst: CM

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	7.5		1	ug/L	15	10/16/2016 12:43 AM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.

S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with * Exceed Regulatory Limit(s). Limit noted.

Date Reported : 10/17/2016



Project Manager : Wayne Bryce

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

Sample Information:

Type : Potable Water
 Origin: Distribution

LABORATORY RESULTS

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

Fort Ann CSD

1 Catherine St

Fort Ann, NY 12827

Attn To : Kevin Lovely

Federal ID :

Collected : 09/26/2016 6:36 AM Point No

Received : 09/27/2016 12:10 PM Location:

Collected By : CLIENT

Lab No. : 1610034-106

Client Sample ID. : C4 A

Analytical Method: E200.8 : IOC

Analyst: CM

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	4.9		1	ug/L	15	10/16/2016 12:46 AM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.


S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with * Exceed Regulatory Limit(s). Limit noted.

Date Reported : 10/17/2016



Project Manager : Wayne Bryce

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

Sample Information:

Type : Potable Water
 Origin: Distribution

LABORATORY RESULTS

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

Fort Ann CSD

1 Catherine St

Fort Ann, NY 12827

Attn To : Kevin Lovely

Federal ID :

Collected : 09/26/2016 6:44 AM Point No

Received : 09/27/2016 12:10 PM Location:

Collected By : CLIENT

Lab No. : 1610034-107

Client Sample ID. : A23 A

Analytical Method: E200.8 : IOC

Analyst: CM

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	4.9		1	ug/L	15	10/16/2016 12:49 AM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.

S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with * Exceed Regulatory Limit(s). Limit noted.

Date Reported : 10/17/2016



Project Manager : Wayne Bryce

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

Sample Information:

Type : Potable Water
 Origin: Distribution

LABORATORY RESULTS

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

Fort Ann CSD

1 Catherine St

Fort Ann, NY 12827

Attn To : Kevin Lovely

Federal ID :

Collected : 09/26/2016 6:45 AM Point No

Received : 09/27/2016 12:10 PM Location:

Collected By : CLIENT

Lab No. : 1610034-108

Client Sample ID. : BR10 A

Analytical Method: E200.8 : IOC

Analyst: CM

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	2.7		1	ug/L	15	10/16/2016 12:52 AM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.


S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with * Exceed Regulatory Limit(s). Limit noted.

Date Reported : 10/17/2016



Project Manager : Wayne Bryce

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

Sample Information:

Type : Potable Water
 Origin: Distribution

LABORATORY RESULTS

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

Fort Ann CSD

1 Catherine St

Fort Ann, NY 12827

Attn To : Kevin Lovely

Federal ID :

Collected : 09/26/2016 6:45 AM Point No

Received : 09/27/2016 12:10 PM Location:

Collected By : CLIENT

Lab No. : 1610034-109

Client Sample ID. : BR10 B

Analytical Method: E200.8 : IOC

Analyst: CM

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	2.7		1	ug/L	15	10/16/2016 12:55 AM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.

S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with * Exceed Regulatory Limit(s). Limit noted.

Date Reported : 10/17/2016



Project Manager : Wayne Bryce

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

Sample Information:

Type : Potable Water
 Origin: Distribution

LABORATORY RESULTS

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

Fort Ann CSD

1 Catherine St

Fort Ann, NY 12827

Attn To : Kevin Lovely

Federal ID :

Collected : 09/26/2016 6:45 AM Point No

Received : 09/27/2016 12:10 PM Location:

Collected By : CLIENT

Lab No. : 1610034-110

Client Sample ID. : BR 10C

Analytical Method: E200.8 : IOC

Analyst: CM

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	5.1		1	ug/L	15	10/16/2016 12:58 AM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.

S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with * Exceed Regulatory Limit(s). Limit noted.

Date Reported : 10/17/2016



Project Manager : Wayne Bryce

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

Sample Information:

Type : Potable Water
 Origin: Distribution

LABORATORY RESULTS

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

Fort Ann CSD

1 Catherine St

Fort Ann, NY 12827

Attn To : Kevin Lovely

Federal ID :

Collected : 09/26/2016 6:45 AM Point No

Received : 09/27/2016 12:10 PM Location:

Collected By : CLIENT

Lab No. : 1610034-111

Client Sample ID. : 101 A

Analytical Method: E200.8 : IOC

Analyst: CM

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	1.8		1	ug/L	15	10/16/2016 1:01 AM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.


S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with * Exceed Regulatory Limit(s). Limit noted.

Date Reported : 10/17/2016



Project Manager : Wayne Bryce

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

Sample Information:

Type : Potable Water
Origin: Distribution

LABORATORY RESULTS

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

Fort Ann CSD

1 Catherine St

Fort Ann, NY 12827

Attn To : Kevin Lovely

Federal ID :

Collected : 09/26/2016 6:46 AM Point No

Received : 09/27/2016 12:10 PM Location:

Collected By : CLIENT

Lab No. : 1610034-112

Client Sample ID. : HF 6

Analytical Method: E200.8 : IOC

Analyst: CM

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	12		1	ug/L	15	10/16/2016 1:16 AM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.


S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with * Exceed Regulatory Limit(s). Limit noted.

Date Reported : 10/17/2016



Project Manager : Wayne Bryce

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

Sample Information:

Type : Potable Water
 Origin: Distribution

LABORATORY RESULTS

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

Fort Ann CSD

1 Catherine St

Fort Ann, NY 12827

Attn To : Kevin Lovely

Federal ID :

Collected : 09/26/2016 6:48 AM Point No

Received : 09/27/2016 12:10 PM Location:

Collected By : CLIENT

Lab No. : 1610034-113

Client Sample ID. : C5 A

Analytical Method: E200.8 : IOC

Analyst: CM

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	* 23	*	1	ug/L	15	10/16/2016 1:18 AM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.


S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with * Exceed Regulatory Limit(s). Limit noted.

Date Reported : 10/17/2016



Project Manager : Wayne Bryce

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

Sample Information:

Type : Potable Water
 Origin: Distribution

LABORATORY RESULTS

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

Fort Ann CSD

1 Catherine St

Fort Ann, NY 12827

Attn To : Kevin Lovely

Federal ID :

Collected : 09/26/2016 6:49 AM Point No

Received : 09/27/2016 12:10 PM Location:

Collected By : CLIENT

Lab No. : 1610034-114

Client Sample ID. : HF 5

Analytical Method: E200.8 : IOC

Analyst: CM

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	1.6		1	ug/L	15	10/16/2016 1:21 AM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.


S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with * Exceed Regulatory Limit(s). Limit noted.

Date Reported : 10/17/2016



Project Manager : Wayne Bryce

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

Sample Information:

Type : Potable Water
 Origin: Distribution

LABORATORY RESULTS

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

Fort Ann CSD

1 Catherine St

Fort Ann, NY 12827

Attn To : Kevin Lovely

Federal ID :

Collected : 09/26/2016 6:51 AM Point No

Received : 09/27/2016 12:10 PM Location:

Collected By : CLIENT

Lab No. : 1610034-115

Client Sample ID. : BR11 A

Analytical Method: E200.8 : IOC

Analyst: CM

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	3.3		1	ug/L	15	10/16/2016 1:24 AM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.

S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with * Exceed Regulatory Limit(s). Limit noted.

Date Reported : 10/17/2016



Project Manager : Wayne Bryce

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

Sample Information:

Type : Potable Water
 Origin: Distribution

LABORATORY RESULTS

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

Fort Ann CSD

1 Catherine St

Fort Ann, NY 12827

Attn To : Kevin Lovely

Federal ID :

Collected : 09/26/2016 6:51 AM Point No

Received : 09/27/2016 12:10 PM Location:

Collected By : CLIENT

Lab No. : 1610034-116

Client Sample ID. : BR11 B

Analytical Method: E200.8 : IOC

Analyst: CM

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	* 25	*	1	ug/L	15	10/16/2016 1:27 AM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.


S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with * Exceed Regulatory Limit(s). Limit noted.

Date Reported : 10/17/2016



Project Manager : Wayne Bryce

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

Sample Information:

Type : Potable Water
 Origin: Distribution

LABORATORY RESULTS

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

Fort Ann CSD

1 Catherine St

Fort Ann, NY 12827

Attn To : Kevin Lovely

Federal ID :

Collected : 09/26/2016 6:51 AM Point No

Received : 09/27/2016 12:10 PM Location:

Collected By : CLIENT

Lab No. : 1610034-117

Client Sample ID. : BR11 C

Analytical Method: E200.8 : IOC

Analyst: CM

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	4.3		1	ug/L	15	10/16/2016 1:30 AM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.

S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with * Exceed Regulatory Limit(s). Limit noted.

Date Reported : 10/17/2016



Project Manager : Wayne Bryce

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

Sample Information:

Type : Potable Water
 Origin: Distribution

LABORATORY RESULTS

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

Fort Ann CSD

1 Catherine St

Fort Ann, NY 12827

Attn To : Kevin Lovely

Federal ID :

Collected : 09/26/2016 6:55 AM Point No

Received : 09/27/2016 12:10 PM Location:

Collected By : CLIENT

Lab No. : 1610034-118

Client Sample ID. : BR12 A

Analytical Method: E200.8 : IOC

Analyst: CM

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	1.9		1	ug/L	15	10/16/2016 1:33 AM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.


S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with * Exceed Regulatory Limit(s). Limit noted.

Date Reported : 10/17/2016



Project Manager : Wayne Bryce

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

Sample Information:

Type : Potable Water
Origin: Distribution

LABORATORY RESULTS

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

Fort Ann CSD

1 Catherine St

Fort Ann, NY 12827

Attn To : Kevin Lovely

Federal ID :

Collected : 09/26/2016 6:55 AM Point No

Received : 09/27/2016 12:10 PM Location:

Collected By : CLIENT

Lab No. : 1610034-119

Client Sample ID. : BR12 B

Analytical Method: E200.8 : IOC

Analyst: CM

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	4.1		1	ug/L	15	10/16/2016 1:36 AM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.

S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with * Exceed Regulatory Limit(s). Limit noted.

Date Reported : 10/17/2016



Project Manager : Wayne Bryce

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

Sample Information:

Type : Potable Water
Origin: Distribution

LABORATORY RESULTS

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

Fort Ann CSD

1 Catherine St

Fort Ann, NY 12827

Attn To : Kevin Lovely

Federal ID :

Collected : 09/26/2016 6:55 AM Point No

Received : 09/27/2016 12:10 PM Location:

Collected By : CLIENT

Lab No. : 1610034-120

Client Sample ID. : BR12 C

Analytical Method: E200.8 : IOC

Analyst: CM

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	1.4		1	ug/L	15	10/16/2016 1:51 AM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.

S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with * Exceed Regulatory Limit(s). Limit noted.

Date Reported : 10/17/2016



Project Manager : Wayne Bryce

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

Sample Information:

Type : Potable Water
 Origin: Distribution

LABORATORY RESULTS

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

Fort Ann CSD

1 Catherine St

Fort Ann, NY 12827

Attn To : Kevin Lovely

Federal ID :

Collected : 09/26/2016 7:00 AM Point No

Received : 09/27/2016 12:10 PM Location:

Collected By : CLIENT

Lab No. : 1610034-121

Client Sample ID. : 201 A

Analytical Method: E200.8 : IOC

Analyst: CM

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	* 25	*	1	ug/L	15	10/16/2016 1:53 AM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.


S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with * Exceed Regulatory Limit(s). Limit noted.

Date Reported : 10/17/2016



Project Manager : Wayne Bryce

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

Sample Information:

Type : Potable Water
 Origin: Distribution

LABORATORY RESULTS

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

Fort Ann CSD

1 Catherine St

Fort Ann, NY 12827

Attn To : Kevin Lovely

Federal ID :

Collected : 09/26/2016 7:00 AM Point No

Received : 09/27/2016 12:10 PM Location:

Collected By : CLIENT

Lab No. : 1610034-122

Client Sample ID. : 201 B

Analytical Method: E200.8 : IOC

Analyst: CM

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	9.6		1	ug/L	15	10/16/2016 1:56 AM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.


S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with * Exceed Regulatory Limit(s). Limit noted.

Date Reported : 10/17/2016



Project Manager : Wayne Bryce

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

Sample Information:

Type : Potable Water
 Origin: Distribution

LABORATORY RESULTS

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

Fort Ann CSD

1 Catherine St

Fort Ann, NY 12827

Attn To : Kevin Lovely

Federal ID :

Collected : 09/26/2016 7:00 AM Point No

Received : 09/27/2016 12:10 PM Location:

Collected By : CLIENT

Lab No. : 1610034-123

Client Sample ID. : 201 C

Analytical Method: E200.8 : IOC

Analyst: CM

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	13		1	ug/L	15	10/16/2016 1:59 AM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.

S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with * Exceed Regulatory Limit(s). Limit noted.

Date Reported : 10/17/2016



Project Manager : Wayne Bryce

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

Sample Information:

Type : Potable Water
 Origin: Distribution

LABORATORY RESULTS

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

Fort Ann CSD

1 Catherine St

Fort Ann, NY 12827

Attn To : Kevin Lovely

Federal ID :

Collected : 09/26/2016 7:00 AM Point No

Received : 09/27/2016 12:10 PM Location:

Collected By : CLIENT

Lab No. : 1610034-124

Client Sample ID. : 201 D

Analytical Method: E200.8 : IOC

Analyst: CM

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	* 29	*	1	ug/L	15	10/16/2016 2:02 AM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.


S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with * Exceed Regulatory Limit(s). Limit noted.

Date Reported : 10/17/2016



Project Manager : Wayne Bryce

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

Sample Information:

Type : Potable Water
 Origin: Distribution

LABORATORY RESULTS

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

Fort Ann CSD

1 Catherine St

Fort Ann, NY 12827

Attn To : Kevin Lovely

Federal ID :

Collected : 09/26/2016 7:00 AM Point No

Received : 09/27/2016 12:10 PM Location:

Collected By : CLIENT

Lab No. : 1610034-125

Client Sample ID. : 201 E

Analytical Method: E200.8 : IOC

Analyst: CM

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	* 17	*	1	ug/L	15	10/16/2016 2:05 AM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.

S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with * Exceed Regulatory Limit(s). Limit noted.

Date Reported : 10/17/2016



Project Manager : Wayne Bryce

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

Sample Information:

Type : Potable Water
 Origin: Distribution

LABORATORY RESULTS

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

Fort Ann CSD

1 Catherine St

Fort Ann, NY 12827

Attn To : Kevin Lovely

Federal ID :

Collected : 09/26/2016 7:00 AM Point No

Received : 09/27/2016 12:10 PM Location:

Collected By : CLIENT

Lab No. : 1610034-126

Client Sample ID. : 201 F

Analytical Method: E200.8 : IOC

Analyst: CM

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	12		1	ug/L	15	10/16/2016 2:08 AM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.


S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with * Exceed Regulatory Limit(s). Limit noted.

Date Reported : 10/17/2016



Project Manager : Wayne Bryce

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

Sample Information:

Type : Potable Water
Origin: Distribution

LABORATORY RESULTS

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

Fort Ann CSD

1 Catherine St

Fort Ann, NY 12827

Attn To : Kevin Lovely

Federal ID :

Collected : 09/26/2016 7:00 AM Point No

Received : 09/27/2016 12:10 PM Location:

Collected By : CLIENT

Lab No. : 1610034-127

Client Sample ID. : 201 G

Analytical Method: E200.8 : IOC

Analyst: CM

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	5.6		1	ug/L	15	10/16/2016 2:11 AM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.

S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with * Exceed Regulatory Limit(s). Limit noted.

Date Reported : 10/17/2016



Project Manager : Wayne Bryce

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

Sample Information:

Type : Potable Water
 Origin: Distribution

LABORATORY RESULTS

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

Fort Ann CSD

1 Catherine St

Fort Ann, NY 12827

Attn To : Kevin Lovely

Federal ID :

Collected : 09/26/2016 7:00 AM Point No

Received : 09/27/2016 12:10 PM Location:

Collected By : CLIENT

Lab No. : 1610034-128

Client Sample ID. : 201 EW

Analytical Method: E200.8 : IOC

Analyst: CM

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	* 19	*	1	ug/L	15	10/16/2016 2:26 AM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.


S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with * Exceed Regulatory Limit(s). Limit noted.

Date Reported : 10/17/2016



Project Manager : Wayne Bryce

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

Sample Information:

Type : Potable Water
 Origin: Distribution

LABORATORY RESULTS

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

Fort Ann CSD

1 Catherine St

Fort Ann, NY 12827

Attn To : Kevin Lovely

Federal ID :

Collected : 09/26/2016 7:04 AM Point No

Received : 09/27/2016 12:10 PM Location:

Collected By : CLIENT

Lab No. : 1610034-129

Client Sample ID. : HF 7

Analytical Method: E200.8 : IOC

Analyst: CM

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	10		1	ug/L	15	10/16/2016 2:28 AM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.


S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with * Exceed Regulatory Limit(s). Limit noted.

Date Reported : 10/17/2016



Project Manager : Wayne Bryce

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

Sample Information:

Type : Potable Water
 Origin: Distribution

LABORATORY RESULTS

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

Fort Ann CSD

1 Catherine St

Fort Ann, NY 12827

Attn To : Kevin Lovely

Federal ID :

Collected : 09/26/2016 7:07 AM Point No

Received : 09/27/2016 12:10 PM Location:

Collected By : CLIENT

Lab No. : 1610034-130

Client Sample ID. : 202 A

Analytical Method: E200.8 : IOC

Analyst: CM

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	* 16	*	1	ug/L	15	10/16/2016 2:31 AM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.


S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with * Exceed Regulatory Limit(s). Limit noted.

Date Reported : 10/17/2016



Project Manager : Wayne Bryce

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

Sample Information:

Type : Potable Water
 Origin: Distribution

LABORATORY RESULTS

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

Fort Ann CSD

1 Catherine St

Fort Ann, NY 12827

Attn To : Kevin Lovely

Federal ID :

Collected : 09/26/2016 7:07 AM Point No

Received : 09/27/2016 12:10 PM Location:

Collected By : CLIENT

Lab No. : 1610034-131

Client Sample ID. : 202 B

Analytical Method: E200.8 : IOC

Analyst: CM

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	12		1	ug/L	15	10/16/2016 2:34 AM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.

S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with * Exceed Regulatory Limit(s). Limit noted.

Date Reported : 10/17/2016



Project Manager : Wayne Bryce

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

Sample Information:

Type : Potable Water
 Origin: Distribution

LABORATORY RESULTS

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

Fort Ann CSD

1 Catherine St

Fort Ann, NY 12827

Attn To : Kevin Lovely

Federal ID :

Collected : 09/26/2016 7:07 AM Point No

Received : 09/27/2016 12:10 PM Location:

Collected By : CLIENT

Lab No. : 1610034-132

Client Sample ID. : 202 C

Analytical Method: E200.8 : IOC

Analyst: CM

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	7.1		1	ug/L	15	10/16/2016 2:37 AM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.

S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with * Exceed Regulatory Limit(s). Limit noted.

Date Reported : 10/17/2016



Project Manager : Wayne Bryce

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

Sample Information:

Type : Potable Water
 Origin: Distribution

LABORATORY RESULTS

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

Fort Ann CSD

1 Catherine St

Fort Ann, NY 12827

Attn To : Kevin Lovely

Federal ID :

Collected : 09/26/2016 7:10 AM Point No

Received : 09/27/2016 12:10 PM Location:

Collected By : CLIENT

Lab No. : 1610034-133

Client Sample ID. : C 6A

Analytical Method: E200.8 : IOC

Analyst: CM

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	* 22	*	1	ug/L	15	10/16/2016 2:40 AM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.

S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with * Exceed Regulatory Limit(s). Limit noted.

Date Reported : 10/17/2016



Project Manager : Wayne Bryce

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

Sample Information:

Type : Potable Water
 Origin: Distribution

LABORATORY RESULTS

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

Fort Ann CSD

1 Catherine St

Fort Ann, NY 12827

Attn To : Kevin Lovely

Federal ID :

Collected : 09/26/2016 7:14 AM Point No

Received : 09/27/2016 12:10 PM Location:

Collected By : CLIENT

Lab No. : 1610034-134

Client Sample ID. : 205 A

Analytical Method: E200.8 : IOC

Analyst: CM

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	* 27	*	1	ug/L	15	10/16/2016 2:43 AM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.


S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with * Exceed Regulatory Limit(s). Limit noted.

Date Reported : 10/17/2016



Project Manager : Wayne Bryce

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

Sample Information:

Type : Potable Water
 Origin: Distribution

LABORATORY RESULTS

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

Fort Ann CSD

1 Catherine St

Fort Ann, NY 12827

Attn To : Kevin Lovely

Federal ID :

Collected : 09/26/2016 7:14 AM Point No

Received : 09/27/2016 12:10 PM Location:

Collected By : CLIENT

Lab No. : 1610034-135

Client Sample ID. : 205 B

Analytical Method: E200.8 : IOC

Analyst: CM

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	* 30	*	1	ug/L	15	10/16/2016 2:46 AM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.


S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with * Exceed Regulatory Limit(s). Limit noted.

Date Reported : 10/17/2016



Project Manager : Wayne Bryce

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

Sample Information:

Type : Potable Water
 Origin: Distribution

LABORATORY RESULTS

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

Fort Ann CSD

1 Catherine St

Fort Ann, NY 12827

Attn To : Kevin Lovely

Federal ID :

Collected : 09/26/2016 7:14 AM Point No

Received : 09/27/2016 12:10 PM Location:

Collected By : CLIENT

Lab No. : 1610034-136

Client Sample ID. : 205 C

Analytical Method: E200.8 : IOC

Analyst: CM

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	* 23	*	1	ug/L	15	10/16/2016 3:01 AM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.


S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with * Exceed Regulatory Limit(s). Limit noted.

Date Reported : 10/17/2016



Project Manager : Wayne Bryce

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

Sample Information:

Type : Potable Water
 Origin: Distribution

LABORATORY RESULTS

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

Fort Ann CSD

1 Catherine St

Fort Ann, NY 12827

Attn To : Kevin Lovely

Federal ID :

Collected : 09/26/2016 7:14 AM Point No

Received : 09/27/2016 12:10 PM Location:

Collected By : CLIENT

Lab No. : 1610034-137

Client Sample ID. : 205 D

Analytical Method: E200.8 : IOC

Analyst: CM

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	* 38	*	1	ug/L	15	10/16/2016 3:04 AM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.

S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with * Exceed Regulatory Limit(s). Limit noted.

Date Reported : 10/17/2016



Project Manager : Wayne Bryce

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

Sample Information:

Type : Potable Water
Origin: Distribution

LABORATORY RESULTS

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

Fort Ann CSD

1 Catherine St

Fort Ann, NY 12827

Attn To : Kevin Lovely

Federal ID :

Collected : 09/26/2016 7:14 AM Point No

Received : 09/27/2016 12:10 PM Location:

Collected By : CLIENT

Lab No. : 1610034-138

Client Sample ID. : 205 E

Analytical Method: E200.8 : IOC

Analyst: CM

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	11		1	ug/L	15	10/16/2016 3:07 AM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.

S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with * Exceed Regulatory Limit(s). Limit noted.

Date Reported : 10/17/2016



Project Manager : Wayne Bryce

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

Sample Information:

Type : Potable Water
 Origin: Distribution

LABORATORY RESULTS

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

Fort Ann CSD

1 Catherine St

Fort Ann, NY 12827

Attn To : Kevin Lovely

Federal ID :

Collected : 09/26/2016 7:14 AM Point No

Received : 09/27/2016 12:10 PM Location:

Collected By : CLIENT

Lab No. : 1610034-139

Client Sample ID. : 205 F

Analytical Method: E200.8 : IOC

Analyst: CM

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	* 61	*	1	ug/L	15	10/16/2016 3:09 AM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.

S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with * Exceed Regulatory Limit(s). Limit noted.

Date Reported : 10/17/2016



Project Manager : Wayne Bryce

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

Sample Information:

Type : Potable Water
 Origin: Distribution

LABORATORY RESULTS

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

Fort Ann CSD

1 Catherine St

Fort Ann, NY 12827

Attn To : Kevin Lovely

Federal ID :

Collected : 09/26/2016 7:14 AM Point No

Received : 09/27/2016 12:10 PM Location:

Collected By : CLIENT

Lab No. : 1610034-140

Client Sample ID. : 205 EW

Analytical Method: E200.8 : IOC

Analyst: CM

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	* 18	*	1	ug/L	15	10/16/2016 3:12 AM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.


S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with * Exceed Regulatory Limit(s). Limit noted.

Date Reported : 10/17/2016



Project Manager : Wayne Bryce

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

Sample Information:

Type : Potable Water
 Origin: Distribution

LABORATORY RESULTS

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

Fort Ann CSD

1 Catherine St

Fort Ann, NY 12827

Attn To : Kevin Lovely

Federal ID :

Collected : 09/26/2016 7:20 AM Point No

Received : 09/27/2016 12:10 PM Location:

Collected By : CLIENT

Lab No. : 1610034-141

Client Sample ID. : HF 8

Analytical Method: E200.8 : IOC

Analyst: CM

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	2.0		1	ug/L	15	10/16/2016 3:15 AM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.

S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with * Exceed Regulatory Limit(s). Limit noted.

Date Reported : 10/17/2016



Project Manager : Wayne Bryce

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

Sample Information:

Type : Potable Water
Origin: Distribution

LABORATORY RESULTS

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

Fort Ann CSD

1 Catherine St

Fort Ann, NY 12827

Attn To : Kevin Lovely

Federal ID :

Collected : 09/26/2016 7:21 AM Point No

Received : 09/27/2016 12:10 PM Location:

Collected By : CLIENT

Lab No. : 1610034-142

Client Sample ID. : BR13 A

Analytical Method: E200.8 : IOC

Analyst: CM

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	6.3		1	ug/L	15	10/16/2016 3:18 AM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.

S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with * Exceed Regulatory Limit(s). Limit noted.

Date Reported : 10/17/2016



Project Manager : Wayne Bryce

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

Sample Information:

Type : Potable Water
 Origin: Distribution

LABORATORY RESULTS

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

Fort Ann CSD

1 Catherine St

Fort Ann, NY 12827

Attn To : Kevin Lovely

Federal ID :

Collected : 09/26/2016 7:21 AM Point No

Received : 09/27/2016 12:10 PM Location:

Collected By : CLIENT

Lab No. : 1610034-143

Client Sample ID. : BR13 B

Analytical Method: E200.8 : IOC

Analyst: CM

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	3.5		1	ug/L	15	10/16/2016 3:21 AM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.


S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with * Exceed Regulatory Limit(s). Limit noted.

Date Reported : 10/17/2016



Project Manager : Wayne Bryce

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

Sample Information:

Type : Potable Water
 Origin: Distribution

LABORATORY RESULTS

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

Fort Ann CSD

1 Catherine St

Fort Ann, NY 12827

Attn To : Kevin Lovely

Federal ID :

Collected : 09/26/2016 7:21 AM Point No

Received : 09/27/2016 12:10 PM Location:

Collected By : CLIENT

Lab No. : 1610034-144

Client Sample ID. : BR13 C

Analytical Method: E200.8 : IOC

Analyst: CM

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	4.8		1	ug/L	15	10/16/2016 3:36 AM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.


S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with * Exceed Regulatory Limit(s). Limit noted.

Date Reported : 10/17/2016



Project Manager : Wayne Bryce

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

Sample Information:

Type : Potable Water
 Origin: Distribution

LABORATORY RESULTS

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

Fort Ann CSD

1 Catherine St

Fort Ann, NY 12827

Attn To : Kevin Lovely

Federal ID :

Collected : 09/26/2016 7:25 AM Point No

Received : 09/27/2016 12:10 PM Location:

Collected By : CLIENT

Lab No. : 1610034-145

Client Sample ID. : 207.5 A

Analytical Method: E200.8 : IOC

Analyst: CM

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	* 17	*	1	ug/L	15	10/16/2016 3:39 AM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.


S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with * Exceed Regulatory Limit(s). Limit noted.

Date Reported : 10/17/2016



Project Manager : Wayne Bryce

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

Sample Information:

Type : Potable Water
 Origin: Distribution

LABORATORY RESULTS

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

Fort Ann CSD

1 Catherine St

Fort Ann, NY 12827

Attn To : Kevin Lovely

Federal ID :

Collected : 09/26/2016 7:28 AM Point No

Received : 09/27/2016 12:10 PM Location:

Collected By : CLIENT

Lab No. : 1610034-146

Client Sample ID. : 206 A

Analytical Method: E200.8 : IOC

Analyst: CM

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	* 54	*	1	ug/L	15	10/16/2016 3:42 AM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.


S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with * Exceed Regulatory Limit(s). Limit noted.

Date Reported : 10/17/2016



Project Manager : Wayne Bryce

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

Sample Information:

Type : Potable Water
 Origin: Distribution

LABORATORY RESULTS

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

Fort Ann CSD

1 Catherine St

Fort Ann, NY 12827

Attn To : Kevin Lovely

Federal ID :

Collected : 09/26/2016 7:28 AM Point No

Received : 09/27/2016 12:10 PM Location:

Collected By : CLIENT

Lab No. : 1610034-147

Client Sample ID. : 206 B

Analytical Method: E200.8 : IOC

Analyst: CM

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	* 34	*	1	ug/L	15	10/16/2016 3:45 AM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.

S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with * Exceed Regulatory Limit(s). Limit noted.

Date Reported : 10/17/2016



Project Manager : Wayne Bryce

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

Sample Information:

Type : Potable Water
 Origin: Distribution

LABORATORY RESULTS

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

Fort Ann CSD

1 Catherine St

Fort Ann, NY 12827

Attn To : Kevin Lovely

Federal ID :

Collected : 09/26/2016 7:28 AM Point No

Received : 09/27/2016 12:10 PM Location:

Collected By : CLIENT

Lab No. : 1610034-148

Client Sample ID. : 206 C

Analytical Method: E200.8 : IOC

Analyst: CM

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	* 42	*	1	ug/L	15	10/16/2016 3:47 AM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.


S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with * Exceed Regulatory Limit(s). Limit noted.

Date Reported : 10/17/2016



Project Manager : Wayne Bryce

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

Sample Information:

Type : Potable Water
 Origin: Distribution

LABORATORY RESULTS

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

Fort Ann CSD

1 Catherine St

Fort Ann, NY 12827

Attn To : Kevin Lovely

Federal ID :

Collected : 09/26/2016 7:28 AM Point No

Received : 09/27/2016 12:10 PM Location:

Collected By : CLIENT

Lab No. : 1610034-149

Client Sample ID. : 206 D

Analytical Method: E200.8 : IOC

Analyst: CM

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	* 29	*	1	ug/L	15	10/16/2016 3:50 AM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.

S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with * Exceed Regulatory Limit(s). Limit noted.

Date Reported : 10/17/2016



Project Manager : Wayne Bryce

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

Sample Information:

Type : Potable Water
 Origin: Distribution

LABORATORY RESULTS

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

Fort Ann CSD

1 Catherine St

Fort Ann, NY 12827

Attn To : Kevin Lovely

Federal ID :

Collected : 09/26/2016 7:28 AM Point No

Received : 09/27/2016 12:10 PM Location:

Collected By : CLIENT

Lab No. : 1610034-150

Client Sample ID. : 206 E

Analytical Method: E200.8 : IOC

Analyst: CM

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	* 52	*	1	ug/L	15	10/16/2016 3:53 AM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.

S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with * Exceed Regulatory Limit(s). Limit noted.

Date Reported : 10/17/2016



Project Manager : Wayne Bryce

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

Sample Information:

Type : Potable Water
 Origin: Distribution

LABORATORY RESULTS

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

Fort Ann CSD

1 Catherine St

Fort Ann, NY 12827

Attn To : Kevin Lovely

Federal ID :

Collected : 09/26/2016 7:28 AM Point No

Received : 09/27/2016 12:10 PM Location:

Collected By : CLIENT

Lab No. : 1610034-151

Client Sample ID. : 206 EW

Analytical Method: E200.8 : IOC

Analyst: CM

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	* 27	*	1	ug/L	15	10/16/2016 3:56 AM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.


S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with * Exceed Regulatory Limit(s). Limit noted.

Date Reported : 10/17/2016



Project Manager : Wayne Bryce

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

Sample Information:

Type : Potable Water
 Origin: Distribution

LABORATORY RESULTS

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

Fort Ann CSD

1 Catherine St

Fort Ann, NY 12827

Attn To : Kevin Lovely

Federal ID :

Collected : 09/26/2016 7:33 AM Point No

Received : 09/27/2016 12:10 PM Location:

Collected By : CLIENT

Lab No. : 1610034-152

Client Sample ID. : 207 A

Analytical Method: E200.8 : IOC

Analyst: CM

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	* 69	*	1	ug/L	15	10/16/2016 4:11 AM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.


S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with * Exceed Regulatory Limit(s). Limit noted.

Date Reported : 10/17/2016



Project Manager : Wayne Bryce

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

Sample Information:

Type : Potable Water
 Origin: Distribution

LABORATORY RESULTS

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

Fort Ann CSD

1 Catherine St

Fort Ann, NY 12827

Attn To : Kevin Lovely

Federal ID :

Collected : 09/26/2016 7:33 AM Point No

Received : 09/27/2016 12:10 PM Location:

Collected By : CLIENT

Lab No. : 1610034-153

Client Sample ID. : 207 B

Analytical Method: E200.8 : IOC

Analyst: CM

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	* 20	*	1	ug/L	15	10/16/2016 4:14 AM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.


S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with * Exceed Regulatory Limit(s). Limit noted.

Date Reported : 10/17/2016



Project Manager : Wayne Bryce

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

Sample Information:

Type : Potable Water
 Origin: Distribution

LABORATORY RESULTS

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

Fort Ann CSD

1 Catherine St

Fort Ann, NY 12827

Attn To : Kevin Lovely

Federal ID :

Collected : 09/26/2016 7:33 AM Point No

Received : 09/27/2016 12:10 PM Location:

Collected By : CLIENT

Lab No. : 1610034-154

Client Sample ID. : 207 C

Analytical Method: E200.8 : IOC

Analyst: CM

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	* 17	*	1	ug/L	15	10/16/2016 4:17 AM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.


S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with * Exceed Regulatory Limit(s). Limit noted.

Date Reported : 10/17/2016



Project Manager : Wayne Bryce

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

Sample Information:

Type : Potable Water
 Origin: Distribution

LABORATORY RESULTS

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

Fort Ann CSD

1 Catherine St

Fort Ann, NY 12827

Attn To : Kevin Lovely

Federal ID :

Collected : 09/26/2016 7:33 AM Point No

Received : 09/27/2016 12:10 PM Location:

Collected By : CLIENT

Lab No. : 1610034-155

Client Sample ID. : 207 D

Analytical Method: E200.8 : IOC

Analyst: CM

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	* 19	*	1	ug/L	15	10/16/2016 4:20 AM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.

S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with * Exceed Regulatory Limit(s). Limit noted.

Date Reported : 10/17/2016



Project Manager : Wayne Bryce

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

Sample Information:

Type : Potable Water
 Origin: Distribution

LABORATORY RESULTS

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

Fort Ann CSD

1 Catherine St

Fort Ann, NY 12827

Attn To : Kevin Lovely

Federal ID :

Collected : 09/26/2016 7:33 AM Point No

Received : 09/27/2016 12:10 PM Location:

Collected By : CLIENT

Lab No. : 1610034-156

Client Sample ID. : 207 E

Analytical Method: E200.8 : IOC

Analyst: CM

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	8.5		1	ug/L	15	10/16/2016 4:23 AM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.


S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with * Exceed Regulatory Limit(s). Limit noted.

Date Reported : 10/17/2016



Project Manager : Wayne Bryce

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

Sample Information:

Type : Potable Water
 Origin: Distribution

LABORATORY RESULTS

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

Fort Ann CSD

1 Catherine St

Fort Ann, NY 12827

Attn To : Kevin Lovely

Federal ID :

Collected : 09/26/2016 7:37 AM Point No

Received : 09/27/2016 12:10 PM Location:

Collected By : CLIENT

Lab No. : 1610034-157

Client Sample ID. : CS 1

Analytical Method: E200.8 : IOC

Analyst: CM

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	* 31	*	1	ug/L	15	10/16/2016 4:25 AM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.

S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with * Exceed Regulatory Limit(s). Limit noted.

Date Reported : 10/17/2016



Project Manager : Wayne Bryce

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

Sample Information:

Type : Potable Water
 Origin: Distribution

LABORATORY RESULTS

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

Fort Ann CSD

1 Catherine St

Fort Ann, NY 12827

Attn To : Kevin Lovely

Federal ID :

Collected : 09/26/2016 7:42 AM Point No

Received : 09/27/2016 12:10 PM Location:

Collected By : CLIENT

Lab No. : 1610034-158

Client Sample ID. : A121

Analytical Method: E200.8 : IOC

Analyst: CM

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	7.5		1	ug/L	15	10/16/2016 4:28 AM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.


S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with * Exceed Regulatory Limit(s). Limit noted.

Date Reported : 10/17/2016



Project Manager : Wayne Bryce

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

Sample Information:

Type : Potable Water
Origin: Distribution

LABORATORY RESULTS

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

Fort Ann CSD

1 Catherine St

Fort Ann, NY 12827

Attn To : Kevin Lovely

Federal ID :

Collected : 09/26/2016 7:42 AM Point No

Received : 09/27/2016 12:10 PM Location:

Collected By : CLIENT

Lab No. : 1610034-159

Client Sample ID. : BR 14

Analytical Method: E200.8 : IOC

Analyst: CM

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	6.1		1	ug/L	15	10/16/2016 4:31 AM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.

S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with * Exceed Regulatory Limit(s). Limit noted.

Date Reported : 10/17/2016



Project Manager : Wayne Bryce

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

Sample Information:

Type : Potable Water
 Origin: Distribution

LABORATORY RESULTS

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

Fort Ann CSD

1 Catherine St

Fort Ann, NY 12827

Attn To : Kevin Lovely

Federal ID :

Collected : 09/26/2016 7:45 AM Point No

Received : 09/27/2016 12:10 PM Location:

Collected By : CLIENT

Lab No. : 1610034-160

Client Sample ID. : 108 A

Analytical Method: E200.8 : IOC

Analyst: CM

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	5.5		1	ug/L	15	10/16/2016 4:46 AM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.


S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with * Exceed Regulatory Limit(s). Limit noted.

Date Reported : 10/17/2016



Project Manager : Wayne Bryce

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

Sample Information:

Type : Potable Water
 Origin: Distribution

LABORATORY RESULTS

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

Fort Ann CSD

1 Catherine St

Fort Ann, NY 12827

Attn To : Kevin Lovely

Federal ID :

Collected : 09/26/2016 7:45 AM Point No

Received : 09/27/2016 12:10 PM Location:

Collected By : CLIENT

Lab No. : 1610034-161

Client Sample ID. : 108 B

Analytical Method: E200.8 : IOC

Analyst: CM

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	5.8		1	ug/L	15	10/16/2016 4:49 AM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.


S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with * Exceed Regulatory Limit(s). Limit noted.

Date Reported : 10/17/2016



Project Manager : Wayne Bryce

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

Sample Information:

Type : Potable Water
 Origin: Distribution

LABORATORY RESULTS

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

Fort Ann CSD

1 Catherine St

Fort Ann, NY 12827

Attn To : Kevin Lovely

Federal ID :

Collected : 09/26/2016 7:45 AM Point No

Received : 09/27/2016 12:10 PM Location:

Collected By : CLIENT

Lab No. : 1610034-162

Client Sample ID. : 108 C

Analytical Method: E200.8 : IOC

Analyst: CM

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	5.1		1	ug/L	15	10/16/2016 4:52 AM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.


S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with * Exceed Regulatory Limit(s). Limit noted.

Date Reported : 10/17/2016



Project Manager : Wayne Bryce

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

Sample Information:

Type : Potable Water
Origin: Distribution

LABORATORY RESULTS

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

Fort Ann CSD

1 Catherine St

Fort Ann, NY 12827

Attn To : Kevin Lovely

Federal ID :

Collected : 09/26/2016 7:45 AM Point No

Received : 09/27/2016 12:10 PM Location:

Collected By : CLIENT

Lab No. : 1610034-163

Client Sample ID. : 108 D

Analytical Method: E200.8 : IOC

Analyst: CM

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	7.4		1	ug/L	15	10/16/2016 4:55 AM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.

S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with * Exceed Regulatory Limit(s). Limit noted.

Date Reported : 10/17/2016



Project Manager : Wayne Bryce

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

Sample Information:

Type : Potable Water
 Origin: Distribution

LABORATORY RESULTS

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

Fort Ann CSD

1 Catherine St

Fort Ann, NY 12827

Attn To : Kevin Lovely

Federal ID :

Collected : 09/26/2016 7:45 AM Point No

Received : 09/27/2016 12:10 PM Location:

Collected By : CLIENT

Lab No. : 1610034-164

Client Sample ID. : 108 E

Analytical Method: E200.8 : IOC

Analyst: CM

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	13		1	ug/L	15	10/16/2016 4:58 AM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.


S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with * Exceed Regulatory Limit(s). Limit noted.

Date Reported : 10/17/2016



Project Manager : Wayne Bryce

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

Sample Information:

Type : Potable Water
 Origin: Distribution

LABORATORY RESULTS

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

Fort Ann CSD

1 Catherine St

Fort Ann, NY 12827

Attn To : Kevin Lovely

Federal ID :

Collected : 09/26/2016 7:49 AM Point No

Received : 09/27/2016 12:10 PM Location:

Collected By : CLIENT

Lab No. : 1610034-165

Client Sample ID. : BR1 A

Analytical Method: E200.8 : IOC

Analyst: CM

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	< 1.0		1	ug/L	15	10/16/2016 5:01 AM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.

S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with * Exceed Regulatory Limit(s). Limit noted.

Date Reported : 10/17/2016



Project Manager : Wayne Bryce

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

Sample Information:

Type : Potable Water
 Origin: Distribution

LABORATORY RESULTS

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

Fort Ann CSD

1 Catherine St

Fort Ann, NY 12827

Attn To : Kevin Lovely

Federal ID :

Collected : 09/26/2016 7:52 AM Point No

Received : 09/27/2016 12:10 PM Location:

Collected By : CLIENT

Lab No. : 1610034-166

Client Sample ID. : BR2 A

Analytical Method: E200.8 : IOC

Analyst: CM

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	2.7		1	ug/L	15	10/16/2016 5:03 AM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.


S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with * Exceed Regulatory Limit(s). Limit noted.

Date Reported : 10/17/2016



Project Manager : Wayne Bryce

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

Sample Information:

Type : Potable Water
 Origin: Distribution

LABORATORY RESULTS

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

Fort Ann CSD

1 Catherine St

Fort Ann, NY 12827

Attn To : Kevin Lovely

Federal ID :

Collected : 09/26/2016 7:52 AM Point No

Received : 09/27/2016 12:10 PM Location:

Collected By : CLIENT

Lab No. : 1610034-167

Client Sample ID. : BR2 B

Analytical Method: E200.8 : IOC

Analyst: CM

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	1.5		1	ug/L	15	10/16/2016 5:06 AM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.


S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with * Exceed Regulatory Limit(s). Limit noted.

Date Reported : 10/17/2016



Project Manager : Wayne Bryce

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

Sample Information:

Type : Potable Water
Origin: Distribution

LABORATORY RESULTS

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

Fort Ann CSD

1 Catherine St

Fort Ann, NY 12827

Attn To : Kevin Lovely

Federal ID :

Collected : 09/26/2016 7:52 AM Point No

Received : 09/27/2016 12:10 PM Location:

Collected By : CLIENT

Lab No. : 1610034-168

Client Sample ID. : BR3 A

Analytical Method: E200.8 : IOC

Analyst: CM

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	1.1		1	ug/L	15	10/16/2016 5:21 AM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.

S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with * Exceed Regulatory Limit(s). Limit noted.

Date Reported : 10/17/2016



Project Manager : Wayne Bryce

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

Sample Information:

Type : Potable Water
 Origin: Distribution

LABORATORY RESULTS

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

Fort Ann CSD

1 Catherine St

Fort Ann, NY 12827

Attn To : Kevin Lovely

Federal ID :

Collected : 09/26/2016 7:52 AM Point No

Received : 09/27/2016 12:10 PM Location:

Collected By : CLIENT

Lab No. : 1610034-169

Client Sample ID. : BR3 B

Analytical Method: E200.8 : IOC

Analyst: CM

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	1.8		1	ug/L	15	10/16/2016 5:24 AM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.


S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with * Exceed Regulatory Limit(s). Limit noted.

Date Reported : 10/17/2016



Project Manager : Wayne Bryce

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

Sample Information:

Type : Potable Water
 Origin: Distribution

LABORATORY RESULTS

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

Fort Ann CSD

1 Catherine St

Fort Ann, NY 12827

Attn To : Kevin Lovely

Federal ID :

Collected : 09/26/2016 8:03 AM Point No

Received : 09/27/2016 12:10 PM Location:

Collected By : CLIENT

Lab No. : 1610034-170

Client Sample ID. : 106 A

Analytical Method: E200.8 : IOC

Analyst: CM

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	9.4		1	ug/L	15	10/16/2016 5:27 AM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.


S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with * Exceed Regulatory Limit(s). Limit noted.

Date Reported : 10/17/2016



Project Manager : Wayne Bryce

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

Sample Information:

Type : Potable Water
 Origin: Distribution

LABORATORY RESULTS

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

Fort Ann CSD

1 Catherine St

Fort Ann, NY 12827

Attn To : Kevin Lovely

Federal ID :

Collected : 09/26/2016 8:03 AM Point No

Received : 09/27/2016 12:10 PM Location:

Collected By : CLIENT

Lab No. : 1610034-171

Client Sample ID. : 106 B

Analytical Method: E200.8 : IOC

Analyst: CM

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	14		1	ug/L	15	10/16/2016 5:30 AM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.

S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with * Exceed Regulatory Limit(s). Limit noted.

Date Reported : 10/17/2016



Project Manager : Wayne Bryce

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

Sample Information:

Type : Potable Water
 Origin: Distribution

LABORATORY RESULTS

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

Fort Ann CSD

1 Catherine St

Fort Ann, NY 12827

Attn To : Kevin Lovely

Federal ID :

Collected : 09/26/2016 8:03 AM Point No

Received : 09/27/2016 12:10 PM Location:

Collected By : CLIENT

Lab No. : 1610034-172

Client Sample ID. : 106 C

Analytical Method: E200.8 : IOC

Analyst: CM

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	7.6		1	ug/L	15	10/16/2016 5:33 AM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.


S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with * Exceed Regulatory Limit(s). Limit noted.

Date Reported : 10/17/2016



Project Manager : Wayne Bryce

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

Sample Information:

Type : Potable Water
 Origin: Distribution

LABORATORY RESULTS

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

Fort Ann CSD

1 Catherine St

Fort Ann, NY 12827

Attn To : Kevin Lovely

Federal ID :

Collected : 09/26/2016 8:12 AM Point No

Received : 09/27/2016 12:10 PM Location:

Collected By : CLIENT

Lab No. : 1610034-173

Client Sample ID. : BGBR

Analytical Method: E200.8 : IOC

Analyst: CM

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	6.7		1	ug/L	15	10/16/2016 5:36 AM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.

S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with * Exceed Regulatory Limit(s). Limit noted.

Date Reported : 10/17/2016



Project Manager : Wayne Bryce

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

Sample Information:

Type : Potable Water
 Origin: Distribution

LABORATORY RESULTS

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

Fort Ann CSD

1 Catherine St

Fort Ann, NY 12827

Attn To : Kevin Lovely

Federal ID :

Collected : 09/26/2016 8:14 AM Point No

Received : 09/27/2016 12:10 PM Location:

Collected By : CLIENT

Lab No. : 1610034-174

Client Sample ID. : BGEW

Analytical Method: E200.8 : IOC

Analyst: CM

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	< 1.0		1	ug/L	15	10/16/2016 5:39 AM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.


S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with * Exceed Regulatory Limit(s). Limit noted.

Date Reported : 10/17/2016



Project Manager : Wayne Bryce

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

Sample Information:

Type : Potable Water
 Origin: Distribution

LABORATORY RESULTS

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

Fort Ann CSD

1 Catherine St

Fort Ann, NY 12827

Attn To : Kevin Lovely

Federal ID :

Collected : 09/26/2016 8:15 AM Point No

Received : 09/27/2016 12:10 PM Location:

Collected By : CLIENT

Lab No. : 1610034-175

Client Sample ID. : BGBR B

Analytical Method: E200.8 : IOC

Analyst: CM

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	1.6		1	ug/L	15	10/16/2016 5:41 AM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.


S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with * Exceed Regulatory Limit(s). Limit noted.

Date Reported : 10/17/2016



Project Manager : Wayne Bryce

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

Sample Information:

Type : Potable Water
 Origin: Distribution

LABORATORY RESULTS

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

Fort Ann CSD

1 Catherine St

Fort Ann, NY 12827

Attn To : Kevin Lovely

Federal ID :

Collected : 09/26/2016 8:16 AM Point No

Received : 09/27/2016 12:10 PM Location:

Collected By : CLIENT

Lab No. : 1610034-176

Client Sample ID. : BGBR G

Analytical Method: E200.8 : IOC

Analyst: CM

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	2.0		1	ug/L	15	10/16/2016 5:56 AM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.


S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with * Exceed Regulatory Limit(s). Limit noted.

Date Reported : 10/17/2016



Project Manager : Wayne Bryce

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

Sample Information:

Type : Potable Water
 Origin: Distribution

LABORATORY RESULTS

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

Fort Ann CSD

1 Catherine St

Fort Ann, NY 12827

Attn To : Kevin Lovely

Federal ID :

Collected : 09/26/2016 8:17 AM Point No

Received : 09/27/2016 12:10 PM Location:

Collected By : CLIENT

Lab No. : 1610034-177

Client Sample ID. : BGHF

Analytical Method: E200.8 : IOC

Analyst: CM

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	< 1.0		1	ug/L	15	10/16/2016 5:59 AM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.


S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with * Exceed Regulatory Limit(s). Limit noted.

Date Reported : 10/17/2016



Project Manager : Wayne Bryce

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

Sample Information:

Type : Potable Water
 Origin: Distribution

LABORATORY RESULTS

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

Fort Ann CSD

1 Catherine St

Fort Ann, NY 12827

Attn To : Kevin Lovely

Federal ID :

Collected : 09/26/2016 8:19 AM Point No

Received : 09/27/2016 12:10 PM Location:

Collected By : CLIENT

Lab No. : 1610034-178

Client Sample ID. : BGS1

Analytical Method: E200.8 : IOC

Analyst: CM

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	* 15	*	1	ug/L	15	10/16/2016 6:02 AM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.


S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with * Exceed Regulatory Limit(s). Limit noted.

Date Reported : 10/17/2016



Project Manager : Wayne Bryce

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

Sample Information:

Type : Potable Water
 Origin: Distribution

LABORATORY RESULTS

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

Fort Ann CSD

1 Catherine St

Fort Ann, NY 12827

Attn To : Kevin Lovely

Federal ID :

Collected : 09/26/2016 8:20 AM Point No

Received : 09/27/2016 12:10 PM Location:

Collected By : CLIENT

Lab No. : 1610034-179

Client Sample ID. : BG

Analytical Method: E200.8 : IOC

Analyst: CM

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	4.3		1	ug/L	15	10/16/2016 6:05 AM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.

S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with * Exceed Regulatory Limit(s). Limit noted.

Date Reported : 10/17/2016



Project Manager : Wayne Bryce

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.



PACE ANALYTICAL
575 Broad Hollow Road
Melville, NY 11747
TEL: (631) 694-3040 FAX: (631) 420-8436
Website: www.pacelabs.com

QC SUMMARY REPORT

WO#: 1610034

17-Oct-16

Client: Fort Ann CSD
Project: LEAD-SCHOOL

BatchID: R107042

Sample ID	CalBlank	SampType: MBLK	TestCode: 200.8_DW_R			Units: ug/L	Prep Date:			RunNo: 107042		
Client ID:	PBW	Batch ID: R107042	TestNo: E200.8			Analysis Date: 10/15/2016			SeqNo: 2380429			
Analyte		Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual
Lead		< 1.0	1.0									

Qualifiers:	* Value exceeds Maximum Contaminant Level	D Dilution was required.	E Value above quantitation range
	H Holding times for preparation or analysis exceeded	M Manual Integration used to determine area response	ND Not Detected at the Reporting Limit
	O RSD is greater than RSDlimit	P Second column confirmation exceeds	R RPD outside accepted recovery limits
	S Spike Recovery outside accepted recovery limits	W Sample container temperature is out of limit as specified	



PACE ANALYTICAL
575 Broad Hollow Road
Melville, NY 11747
TEL: (631) 694-3040 FAX: (631) 420-8436
Website: www.pacelabs.com

QC SUMMARY REPORT

WO#: 1610034

17-Oct-16

Client: Fort Ann CSD
Project: LEAD-SCHOOL

BatchID: R107043

Sample ID	CalBlank	SampType: MBLK	TestCode: 200.8_DW_R			Units: ug/L	Prep Date:			RunNo: 107043		
Client ID:	PBW	Batch ID: R107043	TestNo: E200.8			Analysis Date: 10/15/2016			SeqNo: 2380585			
Analyte		Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual
Lead		< 1.0	1.0									

Qualifiers:	* Value exceeds Maximum Contaminant Level	D Dilution was required.	E Value above quantitation range
H Holding times for preparation or analysis exceeded	M Manual Integration used to determine area response	ND Not Detected at the Reporting Limit	
O RSD is greater than RSDlimit	P Second column confirmation exceeds	R RPD outside accepted recovery limits	
S Spike Recovery outside accepted recovery limits	W Sample container temperature is out of limit as specified		



PACE ANALYTICAL
575 Broad Hollow Road
Melville, NY 11747
TEL: (631) 694-3040 FAX: (631) 420-8436
Website: www.pacelabs.com

Sample Receipt Checklist

Client Name **FASD**

Date and Time Received: **9/27/2016 12:10:00 PM**

Work Order Number: **1610034**

RcptNo: **1**

Received by **Edward Domaradzki**

Completed by:

Reviewed by:

Completed Date: 10/2/2016 6:35:17 PM

Reviewed Date: 10/13/2016 1:40:45 PM

Carrier name: PACE Pickup

Chain of custody present?	Yes <input checked="" type="checkbox"/>	No <input type="checkbox"/>		
Chain of custody signed when relinquished and received?	Yes <input checked="" type="checkbox"/>	No <input type="checkbox"/>		
Chain of custody agrees with sample labels?	Yes <input checked="" type="checkbox"/>	No <input type="checkbox"/>		
Are matrices correctly identified on Chain of custody?	Yes <input checked="" type="checkbox"/>	No <input type="checkbox"/>		
Is it clear what analyses were requested?	Yes <input checked="" type="checkbox"/>	No <input type="checkbox"/>		
Custody seals intact on sample bottles?	Yes <input type="checkbox"/>	No <input type="checkbox"/>	Not Present <input checked="" type="checkbox"/>	
Samples in proper container/bottle?	Yes <input checked="" type="checkbox"/>	No <input type="checkbox"/>		
Were correct preservatives used and noted?	Yes <input checked="" type="checkbox"/>	No <input type="checkbox"/>	NA <input type="checkbox"/>	
Preservative added to bottles:				
Sample Condition?	Intact <input checked="" type="checkbox"/>	Broken <input type="checkbox"/>	Leaking <input type="checkbox"/>	
Sufficient sample volume for indicated test?	Yes <input checked="" type="checkbox"/>	No <input type="checkbox"/>		
Were container labels complete (ID, Pres, Date)?	Yes <input checked="" type="checkbox"/>	No <input type="checkbox"/>		
All samples received within holding time?	Yes <input checked="" type="checkbox"/>	No <input type="checkbox"/>		
Was an attempt made to cool the samples?	Yes <input checked="" type="checkbox"/>	No <input type="checkbox"/>	NA <input type="checkbox"/>	
All samples received at a temp. of > 0° C to 6.0° C?	Yes <input type="checkbox"/>	No <input checked="" type="checkbox"/>	NA <input type="checkbox"/>	
Response when temperature is outside of range:	Not required			
Sample Temp. taken and recorded upon receipt?	Yes <input type="checkbox"/>	No <input checked="" type="checkbox"/>	To °	
Water - Were bubbles absent in VOC vials?	Yes <input type="checkbox"/>	No <input type="checkbox"/>	No Vials <input checked="" type="checkbox"/>	
Water - Was there Chlorine Present?	Yes <input type="checkbox"/>	No <input type="checkbox"/>	NA <input checked="" type="checkbox"/>	
Water - pH acceptable upon receipt?	Yes <input checked="" type="checkbox"/>	No <input type="checkbox"/>	No Water <input type="checkbox"/>	
Are Samples considered acceptable?	Yes <input checked="" type="checkbox"/>	No <input type="checkbox"/>		
Custody Seals present?	Yes <input checked="" type="checkbox"/>	No <input type="checkbox"/>		
Airbill or Sticker?	Air Bil <input type="checkbox"/>	Sticker <input type="checkbox"/>	Not Present <input checked="" type="checkbox"/>	
Airbill No:				

Case Number:

SDG:

SAS:

Any No response should be detailed in the comments section below, if applicable.

Client Contacted? ☐ Yes ☐ No ☒ NA Person Contacted:
Contact Mode: ☐ Phone: ☐ Fax: ☐ Email: ☐ In Person:
Client Instructions:
Date Contacted: Contacted By:
Regarding:
Comments:
CorrectiveAction:

WorkOrder :
1610034

Certifications

STATE	CERTIFICATION #
NEW YORK	10478
NEW JERSEY	NY158
CONNECTICUT	PH-0435
MARYLAND	208
MASSACHUSETTS	M-NY026
NEW HAMPSHIRE	2987
RHODE ISLAND	LAO00340
PENNSYLVANIA	68-00350

1610034

CHAIN-OF-CUSTODY / Analytical Request Document

The Chain-of-Custody is a LEGAL DOCUMENT. All relevant fields must be completed accurately.



Box 1

Section A Required Client Information: Company: Fort Ann CSD Address: 1 Catherine Street, Fort Ann, NY 12827 Email To: klovly@fortannschool.org Phone: 518-839-3594 ext. 3202 Requested Due: Date/TAT: standard		Section B Required Project Information: Report To: Kevin Lovely Copy To: Purchase Order No.: Project Name: Lead-School Project Number:		Section C Invoice Information: Attention: Heather Havens Company Name: Fort Ann CSD Address: 1 Catherine Street, Fort Ann, NY 12827 Place Quote Reference: Capital Region Boces Place Project Manager: Betty Harrison/Wayne Bryos Place Profile #:		REGULATORY AGENCY <input type="checkbox"/> NPDES <input type="checkbox"/> ROUND WATER <input type="checkbox"/> DRINKING WATER <input type="checkbox"/> UST <input type="checkbox"/> CRA <input type="checkbox"/> OT <input type="checkbox"/> ER SITE LOCATION <input type="checkbox"/> GA <input type="checkbox"/> L <input type="checkbox"/> M <input type="checkbox"/> NC <input type="checkbox"/> OH <input type="checkbox"/> SC <input type="checkbox"/> ER Filtered (Y/N)										
Section D Required Client Information SAMPLE ID Character per box. UNIQUE Samples IDs MUST BE 0-9 / (-)	ITEM #	MATRIX CODE	SAMPLE TYPE	G-GRAB C-COMP	COLLECTED		SAMPLE TEMP AT COLLECTION	# OF CONTAINERS	PRESERVATIVES						Requested Analysis	Place Project Number Lab ID
						DATE	TIME	DATE	TIME							
	1	HF1	DW	G		9/26/16	04:20		1							
	2	102A	DW	G		9/26/16	4:22		1							
	3	102B	DW	G		9/26/16	4:25		1							
	4	102C	DW	G		9/26/16	4:28		1							
	5	102D	DW	G		9/26/16	4:30		1							
	6	102E	DW	G		9/26/16	4:31		1							
	7	102F	DW	G		9/26/16	4:30		1							
	8	102G	DW	G		9/26/16	4:32		1							
	9	102H	DW	G		9/26/16	4:33		1							
	10	102EW	DW	G		9/26/16	4:34		1							
11	102I	DW	G		9/26/16	4:35		1								
12	103A	DW	G		9/26/16	4:40		1								

RELINQUISHED BY / AFFILIATION A. H. Fort Ann CSD April Neill 9/26/16 9:00		ACCEPTED BY / AFFILIATION John Neill 9/26/16 10:00		SAMPLE CONDITIONS Temp in °C Received on ice Custody Sealed Cooler Samples Intact	
---	--	---	--	--	--

SAMPLER NAME AND SIGNATURE J. George Longworth SIGNATURE of SAMPLER:		DATE Signed (MM/DD/YY) 9/26/16	
---	--	-----------------------------------	--

Additional Comments:

W

CHAIN-OF-CUSTODY / Analytical Request Document

The Chain-of-Custody is a LEGAL DOCUMENT. All relevant fields must be completed accurately.



Box 2
Page: 3 of 15

Section A Required Client Information:				Section B Required Project Information:				Section C Invoice Information:			
Company: Fort Ann CSD				Report To: Kevin Lovely				Attention: Heather Havens			
Address: 1 Catherine Street, Fort Ann, NY 12827				Copy To:				Company Name: Fort Ann CSD			
Email To: Klovsky@fortannschool.org				Purchase Order No.:				Address: 1 Catherine Street, Fort Ann, NY 12827			
Phone: 518-539-5594 ext. Fax:				Project Name: Lead-School				Place Quote Reference: Capital Region Boces			
Requested Due Date/TAT: standard				Project Number:				Place Project Manager: Betty Harrison/Wayne Bryce			
Section D Required Client Information				Valid Matrix Codes				Preservatives			
SAMPLE ID Character per box. (A-Z, 0-9 / -)				Matrix Code				Unpreserved			
UNIQUE				DATE				DATE			
SAMPLE ID				DATE				DATE			
1 B120 B				9/26/16				05:00			
2 N0A				9/26/16				5:03			
3 N0B				9/26/16				5:03			
4 N0C				9/26/16				5:04			
5 N0D				9/26/16				5:05			
6 B119 A				9/26/16				5:07			
7 B119 B				9/26/16				5:07			
8 B109 A				9/26/16				5:09			
9 B109 B				9/26/16				5:09			
10 B108 A				9/26/16				5:11			
11 B108 B				9/26/16				5:11			
12 B107 A				9/26/16				5:14			
Additional Comments:				RELINQUISHED BY / AFFILIATION				ACCEPTED BY / AFFILIATION			
				J. George Longworth				J. George Longworth			
				DATE SIGNED (MM/DD/YY)				DATE SIGNED (MM/DD/YY)			
				9/26/16				9/26/16			
				TIME				TIME			
				9:26:16				10:00			
				DATE				DATE			
				9/26/16				9/26/16			
				TIME				TIME			
				9:26:16				12:10			
				DATE				DATE			
				9/26/16				9/26/16			
				TIME				TIME			
				9:26:16				12:10			
				DATE				DATE			
				9/26/16				9/26/16			
				TIME				TIME			
				9:26:16				12:10			
				DATE				DATE			
				9/26/16				9/26/16			
				TIME				TIME			
				9:26:16				12:10			
				DATE				DATE			
				9/26/16				9/26/16			
				TIME				TIME			
				9:26:16				12:10			
				DATE				DATE			
				9/26/16				9/26/16			
				TIME				TIME			
				9:26:16				12:10			
				DATE				DATE			
				9/26/16				9/26/16			
				TIME				TIME			
				9:26:16				12:10			
				DATE				DATE			
				9/26/16				9/26/16			
				TIME				TIME			
				9:26:16				12:10			
				DATE				DATE			
				9/26/16				9/26/16			
				TIME				TIME			
				9:26:16				12:10			
				DATE				DATE			
				9/26/16				9/26/16			
				TIME				TIME			
				9:26:16				12:10			
				DATE				DATE			
				9/26/16				9/26/16			
				TIME				TIME			
				9:26:16				12:10			
				DATE				DATE			
				9/26/16				9/26/16			
				TIME				TIME			
				9:26:16				12:10			
				DATE				DATE			
				9/26/16				9/26/16			
				TIME				TIME			
				9:26:16				12:10			
				DATE				DATE			
				9/26/16				9/26/16			
				TIME				TIME			
				9:26:16				12:10			
				DATE				DATE			
				9/26/16				9/26/16			
				TIME				TIME			
				9:26:16				12:10			
				DATE				DATE			
				9/26/16				9/26/16			
				TIME				TIME			
				9:26:16				12:10			
				DATE				DATE			
				9/26/16				9/26/16			
				TIME				TIME			
				9:26:16				12:10			
				DATE				DATE			
				9/26/16				9/26/16			
				TIME				TIME			
				9:26:16				12:10			
				DATE				DATE			
				9/26/16				9/26/16			
				TIME				TIME			
				9:26:16				12:10			
				DATE				DATE			
				9/26/16				9/26/16			
				TIME				TIME			
				9:26:16				12:10			
				DATE				DATE			
				9/26/16				9/26/16			
				TIME				TIME			
				9:26:16				12:10			
				DATE				DATE			
				9/26/16				9/26/16			
				TIME				TIME			
				9:26:16				12:10			
				DATE				DATE			
				9/26/16				9/26/16			
				TIME				TIME			
				9:26:16				12:10			
				DATE				DATE			
				9/26/16				9/26/16			
				TIME				TIME			
				9:26:16				12:10			
				DATE				DATE			
				9/26/16				9/26/16			
				TIME				TIME			
				9:26:16				12:10			
				DATE				DATE			
				9/26/16				9/26/16			
				TIME				TIME			
				9:26:16				12:10			
				DATE				DATE			
				9/26/16				9/26/16			
				TIME				TIME			
				9:26:16				12:10			
				DATE				DATE			
				9/26/16				9/26/16			
				TIME				TIME			
				9:26:16				12:10			
				DATE				DATE			
				9/26/16				9/26/16			
				TIME				TIME			
				9:26:16				12:10			
				DATE				DATE			
				9/26/16				9/26/16			
				TIME				TIME			
				9:26:16				12:10			
				DATE				DATE			
				9/26/16				9/26/16			
				TIME				TIME			
				9:26:16				12:10			
				DATE				DATE			
				9/26/16				9/26/16			
				TIME				TIME			
				9:26:16				12:10			
				DATE				DATE			
				9/26/16				9/26/16			
				TIME				TIME			
				9:26:16				12:10			
				DATE				DATE			
				9/26/16				9/26/16			
				TIME				TIME			
				9:26:16				12:10			
				DATE				DATE			
				9/26/16				9/26/16			
				TIME				TIME			
				9:26:16				12:10			
				DATE				DATE			
				9/26/16				9/26/16			
				TIME				TIME			
				9:26:16				12:10			
				DATE				DATE			
				9/26/16				9/26/16			
				TIME				TIME			
				9:26:16				12:10			
				DATE				DATE			
				9/26/16				9/26/16			
				TIME				TIME			
				9:26:16				12:10			
				DATE				DATE			
				9/26/16				9/26/16			
				TIME				TIME			
				9:26:16				12:10			
				DATE				DATE			
				9/26/16				9/26/16			
				TIME				TIME			
				9:26:16				12:10			
				DATE				DATE			
				9/26/16				9/26/16			
				TIME				TIME			
				9:26:16				12:10			
				DATE				DATE			
				9/26/16				9/26/16			
				TIME				TIME			
				9:26:16				12:10			
				DATE				DATE			
				9/26/16				9/26/16			
				TIME				TIME			
				9:26:16				12:10			
				DATE				DATE			
				9/26/16				9/26/16			
				TIME				TIME			
				9:26:16				12:10			
				DATE				DATE			
				9/26/16				9/26/16			
				TIME				TIME			
				9:26:16				12:10			
				DATE				DATE			
				9/26/16				9/26/16			
				TIME				TIME			
				9:26:16				12:10			
				DATE				DATE			
				9/26/16				9/26/16			
				TIME				TIME			
				9:26:16				12:10			
				DATE				DATE			
				9/26/16				9/26/16			
				TIME				TIME			
				9:26:16				12:10			
				DATE				DATE			
				9/26/16				9/26/16			
				TIME				TIME			
				9:26:16				12:10			
				DATE				DATE			
				9/26/16				9/26/16			
				TIME				TIME			
				9:26:16				12:10			
				DATE				DATE			
				9/26/16				9/26/16			
				TIME				TIME			
				9:26:16				12:10			
				DATE				DATE			
				9/26/16				9/26/16			
				TIME				TIME			
				9:26:16				12:10			
				DATE				DATE			
				9/26/16				9/26/16			
				TIME				TIME			
				9:26:16				12:10			
				DATE				DATE			
				9/26/16				9/26/16			
				TIME				TIME			
				9:26:16				12:10			
				DATE				DATE			
				9/26/16				9/26/16			
				TIME				TIME			
				9:26:16				12:10			
				DATE				DATE			
				9/26/16				9/26/16			
				TIME				TIME			
				9:26:16				12:10			
				DATE				DATE			
				9/26/16				9/26/16			
				TIME				TIME			
				9:26:16				12:10			
				DATE				DATE			
				9/26/16				9/26/16			
				TIME				TIME			
				9:26:16				12:10			
				DATE				DATE			
				9/26/16				9/26/16			
				TIME				TIME			
				9:26:16				12:10			
				DATE				DATE			
				9/26/16				9/26/16			
				TIME				TIME			
				9:26:16				12:10			
				DATE				DATE			
				9/26/16				9/26/16			
				TIME				TIME			
				9:26:16				12:10			
				DATE				DATE			
				9/26/16				9/26/16			
				TIME				TIME			
				9:26:16				12:10			
				DATE				DATE			
				9/26/16				9/26/16			
				TIME				TIME			
				9:26:16				12:10			
				DATE				DATE			
				9/26/16				9/26/16			
				TIME				TIME			
				9:26:16				12:10			
				DATE				DATE			
				9/26/16				9/26/16			
				TIME				TIME			
				9:26:16				12:10			
				DATE				DATE			
				9/26/16				9/26/16			
				TIME				TIME			
				9:26:16				12:10			
				DATE				DATE			

CHAIN-OF-CUSTODY / Analytical Request Document

Pace Analytical
ANALYTICAL SERVICES

Box 3

Section A Required Client Information: Company: Fort Ann CSD Address: 1 Catherine Street, Fort Ann, NY 12827 Email To: klovely@fortannschool.org Phone: 518-839-5584 ext. 52302 Requested Due Date/TAT: standard		Section B Required Project Information: Report To: Kevin Lovely Copy To: Purchase Order No.: Project Name: Lead-School Project Number:		Section C Invoice Information: Attention: Heather Havens Company Name: Fort Ann CSD Address: 1 Catherine Street, Fort Ann, NY 12827 Pace Quote Reference: Capital Region Bocs Pace Project Manager: Betty Harrison/Wayne Byce Pace Profile #:		REGULATORY AGENCY <input type="checkbox"/> NPDES <input type="checkbox"/> ROUNWATER <input type="checkbox"/> DRINKING WATER <input type="checkbox"/> UST <input type="checkbox"/> CRA <input type="checkbox"/> OT/ER		SITE LOCATION <input type="checkbox"/> GA <input type="checkbox"/> L <input type="checkbox"/> M <input type="checkbox"/> NC <input type="checkbox"/> ER <input type="checkbox"/> OH <input type="checkbox"/> SC <input type="checkbox"/> D		Page: 6 of 15											
ITEM #	Section D SAMPLE ID Character per box. 0-9 / -	Section E Required Client Information UNIQUE Samples IDs MUST BE (A-Z)	Valid Matrix Codes WATER WASTE SLURRY OTHER	MATRIX CODE	G-GRAB C-COMP	COLLECTED			# OF CONTAINERS	PRESERVATIVES	SAMPLE TEMP AT COLLECTION	DATE	TIME	RELINQUISHED BY / AFFILIATION	DATE	TIME	ACCEPTED BY / AFFILIATION	DATE	TIME	SAMPLE CONDITIONS	
						COMPOSITE START	COMPOSITE END	DATE													
1	B112 A			DW	G		9/26/16	5:45	1												
2	B112 B			DW	G		9/26/16	5:45	1												
3	B112 C			DW	G		9/26/16	5:45	1												
4	BR6 A			DW	G		9/26/16	5:49	1												
5	BR6 B			DW	G		9/26/16	5:49	1												
6	BR6 C			DW	G		9/26/16	5:49	1												
7	C1 A			DW	G		9/26/16	5:51	1												
8	BR7 A			DW	G		9/26/16	5:53	1												
9	BR7 B			DW	G		9/26/16	5:53	1												
10	BR7 C			DW	G		9/26/16	5:53	1												
11	B113 A			DW	G		9/26/16	5:55	1												
12	B113 B			DW	G		9/26/16	5:55	1												

Additional Comments:

SAMPLER NAME AND SIGNATURE

J. George Longworth

SIGNATURE OF SAMPLER

DATE SIGNED (MM/DD/YY)

9/26/16

Temp in °C

Received on

Sealed Cooler

Samples Intact

Pace Analytical
direct sales worldwide

Box 4

th	1-1	And	DATE Signed (MM/DD/YY)	9/26/16
----	-----	-----	------------------------	---------

The Chain-of-Custody is a LEGAL DOCUMENT. All relevant fields must be completed accurately.

Box 4

91/92/6

The Chain-of-Custody is a LEGAL DOCUMENT. All relevant fields must be completed accurately.

Analytical

Page: 9 of 15

[illegible]



E-File.(ALLO020rev.3.31Mar05), 13Jun2005

The Chain-of-Custody is a LEGAL DOCUMENT. All relevant fields must be completed accurately.



Pace Analytical
 30000 Highway 100, Suite 100
 Houston, TX 77060
 Tel: 281.465.1000
 Fax: 281.465.1001
 Email: info@paceanalytical.com
 Website: www.paceanalytical.com

with _____

		DATE Signed (MM/DD/YY)
		9/26/16

The Chain-of-Custody is a LEGAL DOCUMENT. All relevant fields must be completed accurately.

100th	1-14-16	DATE Signed (MM/DD/YY)	9/26/16
-------	---------	------------------------	---------

Box 6

CHAIN-OF-CUSTODY / Analytical Request Document

The Chain-of-Custody is a LEGAL DOCUMENT. All relevant fields must be completed accurately.



Section A Required Client Information: Company: Fort Ann CSD Address: 1 Catherine Street, Fort Ann, NY 12827 Email To: klovly@fortannschool.org Phone: 518-839-5584 ext. 52502 Requested Due Date/TAT: standard		Section B Required Project Information: Report To: Kevin Lovely Copy To: Purchase Order No.: Project Name: Lead-School Project Number:		Section C Invoice Information: Attention: Heather Havens Company Name: Fort Ann CSD Address: 1 Catherine Street, Fort Ann, NY 12827 Pace Quote Reference: Capital Region Boces Pace Project Manager: Betty Harrison/Wayne Byce Pace Profile #:		REGULATORY AGENCY <input type="checkbox"/> NPDES <input type="checkbox"/> ROUN WATER <input type="checkbox"/> DRINKING WATER <input type="checkbox"/> UST <input type="checkbox"/> CRA <input type="checkbox"/> OT/ER SITE LOCATION <input type="checkbox"/> GA <input type="checkbox"/> L <input type="checkbox"/> M <input type="checkbox"/> NC <input type="checkbox"/> ER <input type="checkbox"/> OH <input type="checkbox"/> SC <input type="checkbox"/> D <input type="checkbox"/> ER		Page: 12 of 15									
ITEM #	Section D Required Client Information SAMPLE ID Character per box 0-9 / - / -	MATRIX CODE	G-GRAB C-COMP	COLLECTED		SAMPLE TEMP AT COLLECTION	# OF CONTAINERS	PRESERVATIVES							Filtered (Y/N)	Requested Analysis	Pace Project Number Lab ID
				DATE	TIME			DATE	TIME	COMPOSITE START	COMPOSITE END	Unpreserved	H ₂ SO ₄	HNO ₃			
1	C6A	DW	G			9/26/16	7:10										
2	205A	DW	G			9/26/16	7:14										
3	205B	DW	G			9/26/16	7:14										
4	205C	DW	G			9/26/16	7:14										
5	205D	DW	G			9/26/16	7:14										
6	205E	DW	G			9/26/16	7:14										
7	205F	DW	G			9/26/16	7:14										
8	205FW	DW	G			9/26/16	7:14										
9	HF8	DW	G			9/26/16	7:20										
10	BR13A	DW	G			9/26/16	7:21										
11	BR13B	DW	G			9/26/16	7:21										
12	BR13C	DW	G			9/26/16	7:21										
Additional Comments:																	
RELINQUISHED BY / AFFILIATION J. George Longworth				ACCEPTED BY / AFFILIATION J. George Longworth				DATE 9/26/16				SAMPLE CONDITIONS Received on ice Sealed Cooler Custody Samples Intact					
SIGNATURE OF SAMPLER: J. George Longworth				DATE SIGNED (MM/DD/YY) 9/26/16				Temp in °C 1000				Received on ice Sealed Cooler Custody Samples Intact					

CHAIN-OF-CUSTODY / Analytical Request Document

The Chain-of-Custody is a LEGAL DOCUMENT. All relevant fields must be completed accurately.

Box 7



Section A
Required Client Information:

Company: Fort Ann CSD
Address: 1 Catherine Street, Fort Ann, NY 12827
Phone: 518-533-5594 ext. 52302
Email To: lovely@fortannschool.org
Project Name: Lead-School
Requested Due Date/TAT: standard

Section B
Required Project Information:

Report To: Kevin Lovely
Copy To:
Purchase Order No.:
Project Number:

Section C
Invoice Information:

Attention: Heather Havens
Company Name: Fort Ann CSD
Address: 1 Catherine Street, Fort Ann, NY 12827
Pace Quote Reference: Capital Region Boces
Pace Project Manager: Betty Harrison/Wayne Boyce
Pace Profile #:

Section D Required Client Information

Character per box. (A-Z, 0-9, /, -) UNIQUE SAMPLE IDs MUST BE

ITEM #	Required Client Information	Valid Matrix Codes	One (A-Z, 0-9, /, -)	UNIQUE	SAMPLE ID	Character per box.
1	207.5 A					
2	206 A					
3	206 B					
4	206 C					
5	206 D					
6	206 E					
7	206 EW					
8	207 A					
9	207 B					
10	207 C					
11	207 D					
12	207 E					

Section E Analytical Request

ITEM #	Matrix Code	Sample Type	G-RAB C-COMP	COLLECTED	SAMPLE TEMP AT COLLECTION	# OF CONTAINERS	Preservatives	Other	Requested Analysis	Filtered (Y/N)	Location	Site	Regulatory Agency
1	DW	G		DATE: 9/26/16 TIME: 7:25		1	H ₂ SO ₄ , HNO ₃ , HCl, NaOH, Na ₂ SiO ₃ , Methanol, Other		Asbestos		GA	NC	
2	DW	G		DATE: 9/26/16 TIME: 7:28		1							
3	DW	G		DATE: 9/26/16 TIME: 7:28		1							
4	DW	G		DATE: 9/26/16 TIME: 7:28		1							
5	DW	G		DATE: 9/26/16 TIME: 7:28		1							
6	DW	G		DATE: 9/26/16 TIME: 7:28		1							
7	DW	G		DATE: 9/26/16 TIME: 7:28		1							
8	DW	G		DATE: 9/26/16 TIME: 7:33		1							
9	DW	G		DATE: 9/26/16 TIME: 7:33		1							
10	DW	G		DATE: 9/26/16 TIME: 7:33		1							
11	DW	G		DATE: 9/26/16 TIME: 7:33		1							
12	DW	G		DATE: 9/26/16 TIME: 7:33		1							

Section F Relinquished By / Affiliation

DATE: 9/26/16 TIME: 10:00 AM
Signature: J. George Longworth
DATE SIGNED: 9/26/16

Section G Sample Conditions

DATE: 9/26/16 TIME: 10:00 AM
Signature: J. George Longworth
DATE SIGNED: 9/26/16

Section H Additional Comments:

1. The first Pace 9/26/16 10:00 AM
2. The second Pace 9/26/16 10:00 AM
3. The third Pace 9/26/16 10:00 AM
4. The fourth Pace 9/26/16 10:00 AM
5. The fifth Pace 9/26/16 10:00 AM
6. The sixth Pace 9/26/16 10:00 AM
7. The seventh Pace 9/26/16 10:00 AM
8. The eighth Pace 9/26/16 10:00 AM
9. The ninth Pace 9/26/16 10:00 AM
10. The tenth Pace 9/26/16 10:00 AM
11. The eleventh Pace 9/26/16 10:00 AM
12. The twelfth Pace 9/26/16 10:00 AM

Box 8

OXACI

3

Page. / { of

c:\pjs\csl\0070rev\3.314a05.13.hmr2005